



005066

PROYECTO:

“RECONSTRUCCIÓN DEL HOSPITAL DE APOYO SAUL GARRIDO ROSILLO II-1, DISTRITO DE TUMBES - PROVINCIA DE TUMBES - DEPARTAMENTO DE TUMBES”

ESPECIALIDAD:

INSTALACIONES MECANICAS

DESCRIPCION:

MEMORIA DE CALCULO

[Signature]
ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

CONFORME

ESPECIALISTA RESPONSABLE:



Ing. Nestor E. Ruiz Ruiz

Reg CIP 29866

[Signature]
MANUEL DANATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 99129

[Signature]
Nestor Enrique Ruiz Ruiz
Ingeniero Mecánico
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

[Signature]
EDWARD CERON TORRES
JEFE DE PROYECTO
REG. CIP N° 99129



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

Contenido

005065

1. CONSIDERACIONES GENERALES	3
2. SISTEMAS DE GASES MEDICINALES	3
2.1. SISTEMA DE OXÍGENO.....	3
2.1.1. CÁLCULO DE LA CENTRAL DE OXIGENO	3
2.1.2. CÁLCULO DEL MANIFOLD DE EMERGENCIA	6
2.2. SISTEMA DE VACÍO CLÍNICO.....	7
2.2.1. CÁLCULO DE LA CAPACIDAD DE LA BOMBA DE VACÍO.....	8
2.3. SISTEMA DE AIRE COMPRIMIDO MEDICINAL	12
2.4. SISTEMA DE COMBUSTIBLES.....	14
3. SISTEMA DE GAS LICUADO DE PETRÓLEO (GLP).....	14
4. SISTEMA DE PETROLEO – BIODIESEL B5	18
5. TRANSPORTE VERTICAL	20
6. SISTEMA DE VAPOR Y RETORNO DE CONDENSADO	23
7. CLIMATIZACIÓN: CALEFACCIÓN, AIRE ACONDICIONADO Y VENTILACIÓN MECÁNICA	27

ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN



CONFORME

Nestor Enrique Ruiz Ruiz
Ingeniero Mecánico
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

EDWARD CERÓN TORRES
JEFE DE PROYECTO
C.I.P. N° 61778



HOSPITAL DE APOYO SAUL GARRIDO ROSILLO II-1

**MEMORIA DE CÁLCULO
INSTALACIONES MECÁNICAS**

[Signature]

ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

1. CONSIDERACIONES GENERALES

Los cálculos desarrollados en el presente documento permitirán determinar las capacidades de los diferentes equipos de los sistemas considerados dentro de lo que corresponde a la especialidad de Instalaciones Mecánicas, de la elaboración del expediente técnico del proyecto del Nuevo Hospital de Apoyo Saul Garrio Rosillo II-1 de Tumbes, que considera:

- Sistemas de Gases Medicinales (Sistema de Oxígeno Medicinal, Vacío Clínico, Aire Comprimido Medicinal, Industrial y Dental) y Aire Comprimido Industrial.
- Sistemas de Combustibles: Gas Licuado de Petróleo (GLP) y Biodiesel – DB5
- Transporte Vertical (Ascensores Públicos, Monta camas y Montacargas).
- Sistema de Vapor y Retorno de Condensado
- Sistema de Climatización (Aire Acondicionado y Ventilación Mecánica).
- Cámaras Frigoríficas

[Signature]

MANUEL DONATO GARCIA DINE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

Para efecto de los cálculos se tomara como base el planteamiento de las salidas de los equipos indicados en el equipamiento

CONFORME

[Signature]

Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866

2. SISTEMAS DE GASES MEDICINALES

Para la determinación de las capacidades de consumo de gases medicinales e industrial, se tiene que contabilizar la cantidad de puntos de salida de cada tipo indicados en los planos de equipamiento. (Se utilizará como referencia las Normas de Diseño de Ingeniería del Instituto Mexicano del Seguro Social - IMSS), sin embargo, para el desarrollo a nivel de anteproyecto se considerará un estimado aproximado según el diseño arquitectónico, lo cual se reajustará en el diseño definitivo del proyecto en base a lo cual se realiza el diseño de los gases medicinales



2.1. SISTEMA DE OXÍGENO

Se ha considerado la distribución de las salidas indicadas en el equipamiento de los servicios de hospitalización, centro quirúrgico, centro obstétrico, cirugía, emergencia y demás equipos que requieran oxígeno, de acuerdo al programa de equipamiento

EDWARD CERÓN TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

2.1.1. CÁLCULO DE LA CENTRAL DE OXIGENO

El sistema de oxígeno medicinal comprende una estación central, compuesta por una central generadora de oxígeno medicinal de grado médico, certificada como un dispositivo medico clase IIB y un par de bancadas de cilindros de 10 m³ cada uno, así como una red de distribución desde la central hasta cada uno de los puntos de utilización.

CONSORCIO CONSULTOR SAUL GARRIDO

10/10/2020

Handwritten signature and stamp

Handwritten text and stamp

Handwritten text and stamp



Handwritten text at the bottom left

Handwritten text at the bottom left



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005063

Se considerarán los criterios establecidos en la NFPA 99, ASME B31.3, ISO 10083:2006 y en los "Criterios Normativos de Ingeniería" del Instituto Mexicano del Seguro Social "Para el número de salidas y tipo en función al ambiente", los cuales establecen los niveles de consumo y en las cuales se requieren establecer los siguientes aspectos.

Parámetros:

- Cantidad de salidas
- Características de los ambientes.

ARQ. DAVID HECTOR TORRES PUNTE
CAP. 5176
JEFE DE SUPERVISIÓN

Distribución de salidas:

Según el programa de equipamiento se tiene para 51 camas hospitalarias que adicionamos 50% considerando requerimiento de salidas en otros ambientes, para efectos de diseño tomamos 80 salidas equivalentes de oxígeno medicinal.

ABASTECIMIENTO Y DISTRIBUCIÓN DE OXÍGENO Y ÓXIDO NITROSO

Tabla.- Guía de salida de murales y tipo de uso

LOCAL	Nº DE SALIDAS				Tipo de uso	OBSERVACIONES
	Oxígeno	Aire comp.	Óxido nitroso	Vácuo directo		
Sala de cirugía (1)	4	4	2	4+1(s)	A	Por sala excepto H. Esp.(6)
Sala de cirugía de gineco (2)	4	4	2	4+1(s)	A	Por sala
Sala de expulsión (3)	2	2		2	A	Por sala
Recuperación post-operatoria (4)	1	1		1	A	Por cama(100%)
Cuidados intensivos	2	2		2	A	Por cama(100%)
Trabajos de parto	1	1		1	A	Por cama(100%)
Recuperación post parto (4)	1	1		1	A	Por cama(100%)
Cuidados intermedios	1	1		1	A	Por cama
Terapia intravítrea	1	1		1	A	Por cama o camilla
Observación urgencia adultos (4)	1	1		1	A	Por cama o camilla
Rehidratación mesa Karam	1	2		1	A	Por cada cuna
Aislados adultos en H.G.Z	1	1		1	A	Por cada aislado
Aislados adultos en H.G.E	1	1		1	A	Por cada aislado
Aislado pediatría en H.G.Z	2	2		1	A	Por aislado
Aislado pediatría en H.G.E	2	2		1	A	Por aislado
Observación pediatría (4)	1	1		1	A	1 por cama o cuna
Cuarto de shock	2	2		2	A	Por cama
Recuperación de transición cuneros	1	1			B	Por cada tres cunas
Encamados adultos H.G.Z	1	1		1	B	Por cama
Encamados adultos H.G.E	1	1		1	B	Por cama
Encamado gineco	1	2			B	En dos de cada tres camas
Encamados generales pediatría H.G.Z	1	2			B	Por cama
Encamados generales pediatría H.G.E	1	1		1	B	Por cama
Encamados generales pediatría gineco	1	2			B	En dos de cada tres camas
Prematuros	1	1		1	B	Por incubadora
Cunero fisiológico	1	1		1	B	Por cada tres cunas
Cunero patológico	1	1		1	B	Por cuna
C.E.Y.E		1			B	
Laboratorio clínico					B	Veá guía mecánica
Mesa de autopsias		1			B	
Estomatología		1			B	Cuando sean mas de 2 sillones
Bomba de cobalto	1	1			B	Por sala
Diálisis	1	1		1	B	Por cada 3 sillones
Hemodiálisis	1	1		1	B	Por sillón
Inhaloterapia	1	1			B	Por sillón
Quimioterapia	1	1			B	Por cada 4 sillones
Endoscopia	1	1			B	Por gabinete
Tomografía	1	1			B	Por sala
Resonancia magnética	1	1			B	Por sala
Rayos "X"	1	1			B	Por sala
Hemodinamia	1	1			B	Por sala
Centellografía	1	1			B	Por sala
Gamagrafía	1	1			B	Por sala
Cirugía ambulatoria	1	1			B	50% de camas
Puerperio de bajo riesgo	1	1			B	50% de camas
Primer contacto	1	1			B	Por cama
Curaciones	1	1			B	Por cama

CONFORME

MANUEL DONATO GARCIA JAVE
ING. MECÁNICO-ELECTRICISTA
REG. CIP N° 69138

Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866

- Se instalarán bombas de vacío en unidades con mas de 2salas de operaciones ó 2 salas de expulsión
- 1.-En dos torretas
 - 2.- En dos torretas y agregar 1 toma de oxígeno y 1 toma de aire para el recién nacido.
 - 3.- En una torreta y agregar 1 toma de oxígeno y 1 toma de aire para el recién nacido.
 - 4.-Si no hay línea de succión, instalar dos tomas de aire comprimido.
 - 5.- La salida adicional de vacío indicada en las salas de cirugía será para conectar evacuaciones de gases anestésicos de desechos
 - 6.- En hospitales de especialidades consultar guía mecánica, lo mínimo que llevaran es lo establecido en esta tabla.

Tabla 01.- Distribución de salidas de Oxígeno Medicinal



CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
O.N.I N° 21546425

EDWARD CERÓN TORRES

JEFE DE PROYECTO

C.I.P. N° 61778



[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

Cuadro N° 02
GASTO DE OXÍGENO EN FUNCIÓN DEL NÚMERO DE SALIDAS

N° de Salidas	Gasto l/min	CFM	N° de Salidas	Gasto l/min	CFM	N° de Salidas	Gasto l/min	CFM
1	100	3.53	110	949	33.50	300	1425	10.59
2	148	5.22	120	979	34.56	320	1461	11.30
3	181	6.39	130	1009	35.62	340	1495	12.00
4	210	7.41	140	1039	36.68	360	1527	12.71
5	237	8.37	150	1068	37.70	380	1558	13.41
6	261	9.21	160	1096	38.69	400	1588	14.12
7	283	9.99	170	1122	39.61	420	1618	14.83
8	302	10.66	180	1148	40.53	440	1647	15.53
9	320	11.30	190	1174	41.44	460	1675	16.24
10	336	11.86	200	1200	42.36	480	1702	16.94
15	399	14.09	210	1225	43.24	500	1728	17.65
20	448	15.81	220	1249	44.09	550	1788	19.42
30	533	18.82	230	1273	44.94	600	1847	21.18
40	607	21.43	240	1296	45.75	650	1904	22.95
50	676	23.86	250	1319	46.56	700	1958	24.71
70	780	27.53	260	1341	47.34	750	2011	26.48
80	827	29.19	270	1363	48.11	800	2062	28.24
90	872	30.78	280	1384	48.86	850	2112	30.01
100	915	32.30	290	1405	49.60	900	2160	31.77

REF. Tabla13.2 Normas del IMSS.

Tabla 02.- Gastos de oxígeno en función al numero de salidas

Tomando en cuenta el cuadro N°1 del IMSS para 80 salidas se tiene un gasto total en máxima demanda de **827 lt/min** (REF. Tabla13.2 Normas del IMSS).

[Signature]
 Walter Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

Consumo de oxigeno para 80 salidas	827 lpm
Funcionamiento	24 h
Factor de uso	0.25
Consumo horario teorico	12.40 m ³ /h
Factor de seguridad	1.2
Demanda horaria	14.88 m ³ /h



[Signature]
 MANUEL DONATO GARCIA JIMENEZ
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

CONFORME

Para efectos de la selección de la planta generadora de oxígeno medicinal se considera una Planta dúplex de producción de 20 m³/h, respaldada con un manifold de emergencia

CONSORCIO CONSULTOR SAUL GARRIDO

[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 D.M.I. N° 21546025



CONSORCIO CONSULTOR SAUL GARRIDO RUC 20607759538

2.1.2. CÁLCULO DEL MANIFOLD DE EMERGENCIA

005061

Para casos de emergencia se dispondrá de botellas de oxígeno de 10 m3 cada una, que sean capaces de cubrir la demanda durante 24 horas seguidas considerando un factor de uso de 25% se tiene

Consumo horario	14.88 m3/h
Funcionamiento diario	24 h
Demanda diaria	357.12 m3
Capacidad de balones	10 m3/balon
Cantidad de balones	35.71 m3
Manifold duplex	2 x 18 balones


 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

Se propone un manifold dúplex de dos (2) bancadas de 18 cilindros de 10m3 cada una que estará conformada en dos filas de 9 balones por bancada

Determinación de la Caída de Presión

El criterio para determinar las caídas de presiones en cada uno de los tramos consiste en analizar el circuito más crítico, considerando que la caída de presión total debido a las tuberías, válvulas y accesorios sea menor de 0.28 kg/cm2 (4 psi), que es la pérdida máxima exigida por las Normas y tomando en cuenta el gasto en cada tramo. Las presiones de trabajo de las tuberías de la red de distribución serán de 3.87 kg/cm2 (g) en su inicio y mínima de 3.59 kg/cm2 (g) al final, es decir la salida más lejana

CONFORME



 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866


 MANUEL BUNATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138




CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.G. MARTA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 ONI N° 21946425


 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

005660



[Signature]
 DR. DAVID LECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

[Signature]
 MANUEL DONATO GARCIA JAVÉ
 ING. MECÁNICO-ELECTRICISTA
 REG. CIP N° 10130

CONFORME

Tabla N° 03 Determinación de las pérdidas de presión de las redes de oxígeno en función del gastos de oxígeno y del diámetro de la tubería

Mediante este nomograma nos permite determinar los diámetros de las redes de oxígeno, considerando la caída de presión del sistema.

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

2.2. SISTEMA DE VACÍO CLÍNICO

Se considera los criterios establecidos en la NFPA 99, ASME B31.3, ISO 7396-1 y los "Criterios Normativos de Ingeniería" del Instituto Mexicano del Seguro Social "Para el número de salidas y tipo en función del ambiente", los cuales establecen los niveles de consumo. Para el presente proyecto se considerará una planta de vacío con dos (2) equipos productores de vacío, con vacíos entre 19" Hg y de 25" Hg, uno para servicio normal y otro de reserva.

- Parámetros:
- Número de salidas

Características de los ambientes de acuerdo con las funciones que estos cumplen
 El sistema consiste en una central dúplex compuesta principalmente por un par de bombas de vacío (una de operación continua y otra de respaldo) impulsadas por motor eléctrico, y un tanque receptor. El cálculo se destina a la determinación de la capacidad de las bombas de vacío, con la

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 65744



CONSORCIO CONSULTOR SAUL GARRIDO RUC 20607759538

005059

cual queda determinada la central.

2.2.1. CÁLCULO DE LA CAPACIDAD DE LA BOMBA DE VACÍO

Consiste en una central dúplex compuesta principalmente por un par de bombas de vacío (una de operación continua y otra de respaldo) impulsadas por motor eléctrico, y un tanque receptor. El cálculo se destina a la determinación de la capacidad de las bombas de vacío, con la cual queda determinada la central.

GASTO: (ANEXO 5) PARA 80 SALIDAS	350.7	lpm
FACTOR DE SIMULTANEIDAD	0.8	
GASTO MÁXIMA DEMANDA TOTAL	280.56	lpm
FACTOR DE CONVERSION PARA 19" Hg:	28.3	
GASTO MÁXIMA DEMANDA TOTAL (ACFM)	.9.91	ACFM


 ARQ. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN


 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Se ha considerado 80 salidas equivalentes de Vacío, mediante las Tablas del **ANEXO 5** el gasto de 350.70 lpm de, mediante de un factor de simultaneidad de 0.8, se tiene un gasto de **280.56 l/min. (9.91 ACFM)**

Para el presente proyecto se está estimando **02 bombas de vacío** c/u de capacidad de **280.56 l/min. (9.91 ACFM)** y motor de **7.5 HP** c/u, uno para servicio normal y el otro en reserva, con un tanque pulmón de **120 galones**

La capacidad de la bomba deberá garantizar una presión de vacío de 19" (482.6 mm) de columna de mercurio.

CONFORME

Determinación de la Caída de Presión

El criterio para determinar las caídas de presiones en cada uno de los tramos consiste en analizar el circuito más crítico, considerando que la caída de presión total debido a las tuberías, válvulas y accesorios sea menor de 76.2 mm de columna de mercurio (0.104 kg/cm²), que es la pérdida máxima exigida por las Normas y tomando en cuenta el gasto en cada tramo. El vacío de trabajo en las redes de succión será de 482.6 mmHg en su inicio y de 406.0 mmHg en la salida más alejada


 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138



 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866



Tabla de gastos del sistema de Vacío. Ref IMSS

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425


 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005058

Tabla 15.1 Salidas "A" Gastos en función del número de salidas

Nº de salidas	Gasto LPM	Nº de salidas	Gasto LPM	Nº de salidas	Gasto LPM	Nº de salidas	Gasto LPM
1	42.60	41	547.90	81	646.80	210	790.50
2	85.20	42	551.10	82	648.70	220	799.80
3	127.80	43	554.30	83	650.50	230	809.00
4	170.40	44	557.40	84	652.30	240	818.30
5	213.00	45	560.50	85	654.00	250	827.60
6	255.60	46	563.50	86	655.80	260	836.70
7	298.20	47	566.60	87	657.50	270	846.10
8	340.80	48	569.50	88	659.20	280	855.40
9	364.00	49	572.40	89	660.90	290	864.70
10	390.00	50	575.30	90	662.50	300	874.00
11	394.00	51	577.90	91	664.20	310	883.20
12	407.00	52	580.70	92	665.80	320	892.50
13	419.00	53	583.40	93	667.40	330	901.80
14	428.00	54	586.10	94	669.00	340	911.10
15	437.00	55	588.80	95	670.50	350	920.30
16	445.00	56	591.50	96	672.10	360	929.60
17	452.00	57	594.10	97	673.60	370	938.90
18	458.00	58	596.70	98	675.10	380	948.20
19	463.00	59	599.20	99	676.60	390	957.40
20	467.70	60	601.70	100	678.00	400	966.70
21	472.50	61	604.20	101	685.10	420	985.30
22	477.00	62	606.60	102	691.70	440	1003.80
23	481.50	63	609.00	103	698.00	460	1022.40
24	485.80	64	611.40	104	704.00	480	1040.90
25	489.90	65	613.70	105	709.70	500	1059.50
26	493.90	66	616.00	106	715.10	520	1078.00
27	497.90	67	618.20	107	720.30	540	1096.60
28	501.70	68	620.50	108	725.30	560	1115.10
29	505.60	69	622.70	109	730.10	580	1133.60
30	509.40	70	624.90	110	734.90	600	1152.20
31	513.10	71	627.00	111	739.50	620	1170.70
32	516.80	72	629.10	112	744.10	640	1189.30
33	520.50	73	631.20	113	748.80	660	1207.80
34	524.10	74	633.20	114	753.40	680	1226.40
35	527.60	75	635.30	115	758.00	700	1244.90
36	531.10	76	637.30	116	762.70	720	1263.50
37	534.50	77	639.20	117	767.30	740	1282.00
38	537.90	78	641.20	118	771.90	750	1291.30
39	541.30	79	643.10	119	776.60		
40	544.60	80	645.00	120	781.20		


 ARQ. DAVID HECTOR TORRES PUNTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



 Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866




 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425


 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.F.



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005057

Tabla 15.2 Salidas "B" Gastos en función del número de salidas

Nº de salidas	Gasto LPM	Nº de salidas	Gasto LPM	Nº de salidas	Gasto LPM	Nº de salidas	Gasto LPM
1	42.60	41	272.70	81	352.30	210	534.10
2	80.00	42	275.10	82	353.90	220	548.10
3	103.80	43	277.50	83	355.50	230	262.10
4	119.60	44	279.80	84	357.00	240	576.20
5	132.40	45	282.10	85	358.50	250	590.20
6	142.70	46	284.40	86	360.00	260	604.20
7	153.00	47	286.70	87	361.50	270	618.20
8	160.00	48	289.00	88	363.00	280	632.30
9	166.60	49	291.20	89	363.40	290	646.30
10	173.50	50	293.40	90	365.80	300	660.30
11	179.80	51	295.60	91	367.20	310	674.30
12	185.50	52	297.80	92	368.60	320	688.30
13	190.70	53	300.00	93	370.00	330	702.40
14	195.50	54	302.10	94	371.40	340	716.40
15	199.80	55	304.20	95	372.80	350	730.40
16	203.90	56	306.30	96	374.20	360	744.40
17	207.60	57	308.40	97	375.60	370	758.50
18	211.20	58	310.50	98	377.00	380	772.50
19	214.50	59	312.50	99	378.40	390	786.50
20	217.60	60	314.50	100	379.90	400	800.50
21	220.70	61	316.50	105	386.90	420	828.60
22	223.60	62	318.50	110	393.90	440	856.60
23	226.40	63	320.50	115	400.90	460	884.70
24	229.20	64	322.40	120	407.90	480	912.70
25	231.90	65	324.30	125	414.90	500	940.80
26	234.60	66	326.20	130	421.90	520	968.80
27	237.30	67	328.10	135	428.90	540	996.80
28	240.00	68	330.00	140	435.90	560	1024.90
29	242.60	69	331.80	145	443.00	580	1052.90
30	245.20	70	333.60	150	450.00	600	1081.00
31	247.80	71	335.40	155	457.00	620	1109.00
32	250.40	72	337.20	160	464.00	640	1137.10
33	253.00	73	339.00	165	471.00	660	1165.10
34	255.50	74	340.70	170	478.00	680	1193.20
35	258.00	75	342.40	175	485.00	700	1221.20
36	260.50	76	344.10	180	492.00	720	1249.20
37	263.00	77	345.80	185	499.00	740	1277.30
38	265.50	78	347.50	190	506.00	750	1291.30
39	267.90	79	349.10	195	513.10		
40	270.30	80	350.70	200	520.10		


 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN





CONFORME



 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866


 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 59138

CONSORCIO CONSULTOR SAUL GARRIDO


 C.P.C. MARIA LUISA CARBALLO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425


 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 11111



[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 09138

CONFORME

Figura 15.1 Vacío o succión. Para presiones de 380.0 a 342.0 mm de mercurio absolutas



Mediante este nomograma nos permite determinar los diámetros de las redes de vacío, para lo cual se deberá considerar la máxima caída de presión permisible del sistema.

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DMI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770



[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

[Signature]
 MANUEL DONATO GARCÍA JAYE
 ING. MECÁNICO-ELECTRICISTA
 REG. CIP N° 69138

2.3. SISTEMA DE AIRE COMPRIMIDO MEDICINAL

Aire Comprimido Medicinal

Se tiene para 18 salidas de las normas del IMSS lo siguiente

GASTO ACM (ANEXO 2) PARA 18 SALIDAS TIPO B	429.0	LPM
FACTOR DE SIMULTANEIDAD	1	
GASTO MAXIMA DEMANDA TOTAL	429.0	lpm
FACTOR DE CONVERSION	28.33	
GASTO MAXIMA DEMANDA TOTAL (ACFM)	15.15	ACFM



Se ha considerado una clasificación de tipos de salidas según el ambiente el cual va ser suministrado de aire comprimido medicinal. Tipo "A" para consumos masivos y Tipo "B" o equivalentes para consumo menores, las salidas se clasifican según la **Tabla N° 01**, de distribución de salidas, que se toma de forma similar a la de Oxígeno. Para efectos de cálculo de capacidades, se uniformiza a salidas equivalentes Tipo "B", convirtiendo mediante la aplicación de un factor ("factor 4" para las salas de cirugías y "2" para las demás áreas del mismo tipo de salida). Como resultado obtenemos 124 salidas equivalentes del Tipo "B" y mediante la **Tabla N° 02**, se determina el Gasto Total.

Para el presente proyecto se está estimando 2 compresores de aire de tipo scroll medicinal oil – less (no se permiten compresores lubricados por aceite) c/u de **15.15 ACFM (429 lpm)**, con una potencia aproximada de motor de **7.5 HP** c/u, uno de ellos será para servicio normal y el otro para de reserva con un tanque de almacenamiento de 120 Gal.

Aire Comprimido Industrial

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

DESCRIPCIÓN	Cantidad	Gasto l/min	Total Gasto l/min
Taller de Mantenimiento equipos médicos	4	40	160.00
Lavandería y planchado	3	100	300.00
Sala de partos	2	50	100.00
Sala de Operaciones	4	50	300.00
Autoclave de desechos	2	120	360.00
Gasto Total		1,000	
Factor de Simultaneidad		0.5	
Gasto Máxima Demanda Total		500.0 l/min	17.65 ACFM

CONFORME

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Para determinar las caídas de presiones se utilizó el nomograma Tabla N° 03 (ref. Fig 13.1 del IMSS). El criterio para determinar las caídas de presiones en cada uno de los tramos



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005054

consiste en analizar el circuito más crítico, considerando que la caída de presión total debido a las tuberías, válvulas y accesorios sea menor de 0.28 kg/cm² (4 Psi), que es la pérdida máxima exigida por las Normas y tomando en cuenta el gasto en cada tramo.

Para el sistema de Aire Comprimido Industrial duplex, se está estimando dos compresoras de aire de **7.5 HP** c/u, de producción de **17.65 ACFM**, una de ellas en servicio y la otra de reserva (ver catálogo), con un tanque de almacenamiento de 120 gal, con una tolerancia de más/menos 15%

Aire Comprimido Dental

Cálculo realizado para tres salidas x 80 L/min

ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

CENTRAL DE AIRE UNIDAD DENTAL		
Consumo x salida	240	l/min
Factor Simultaneidad	1.0	
Capacidad de Central (l/min)	240	l/min
Capacidad Total:	8	ACFM

CONFORME

Para determinar las caídas de presiones se utilizó el nomograma Tabla N° 03 (ref. Fig 13.1 del IMSS). El criterio para determinar las caídas de presiones en cada uno de los tramos consiste en analizar el circuito más crítico, considerando que la caída de presión total debido a las tuberías, válvulas y accesorios sea menor de 0.28 kg/cm² (4 Psi), que es la pérdida máxima exigida por las Normas y tomando en cuenta el gasto en cada tramo

Se ha considerado para efectos de cálculo un factor de simultaneidad de 1.0.

Para el presente proyecto se está estimando 2 compresores de aire para unidad dental de 8.0 ACFM, 3.0 HP, uno de ellos será para servicio normal y el otro será de reserva (Valores obtenidos de catálogos).

CRITERIOS PARA LA SELECCIÓN DE LAS TUBERÍAS EN SISTEMAS DE OXÍGENO, AIRE COMPRIMIDO Y VACÍO

Para la selección de los diámetros se han considerado los nomogramas mencionados en los **ANEXOS 3 y 6**, los cuales han sido elaborados utilizando la fórmula de Darcy:

$$\Delta P_{100} = 237.2264 f \frac{P_o q_o}{P_i d^5}$$

ΔP : Pérdida por fricción del tubo en kg/cm².

f: Factor de fricción.

EDWARD CERÓN TORRES
JEFE DE PROYECTO
C.I.E. N° 61770
CONSORCIO CONSULTOR SAUL GARRIDO



- Po: Peso específico del gas en condiciones estándar en kg/m³.
- Pi: Presión absoluta de operación en el interior del tubo en kg/cm².
- Qo: Gasto del gas en las condiciones estándar, en litros por minuto.
- d: Diámetro interior del tubo en milímetros.

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

Para la determinación del valor del factor de fricción se utilizó la fórmula de Swamee-Jain cuya expresión es:

$$f = \frac{0.25}{[\log(\frac{\epsilon}{3.7d} + \frac{5.74}{Rn^{0.9}})]^2}$$

- ε: Rugosidad absoluta de las paredes interiores del tubo en milímetros habiéndose considerado ε= 0.001524 mm.
- d: Diámetro interior del tubo en mm.
- Rn: Número de Reynolds.

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 00100

CONFORME

Para el caso del Sistema de Vacío la variación de pérdidas por cada 100 m estará expresada en mm de columna de mercurio.

2.4. SISTEMA DE COMBUSTIBLES

Para la determinación de las capacidades de utilización de los combustibles se ha considerado el equipamiento definido por cada una de las especialidades

3. SISTEMA DE GAS LICUADO DE PETRÓLEO (GLP)

El suministro de GLP proviene desde el Tanque de Almacenamiento de GLP desde el cual se conecta a la Válvula de Regulación (entre 0.4 – 4.0 bar), regulada a 1 bar (g) a la salida, para suministrar combustible a la Sala de Calderos y Calentadores de agua.

[Signature]
 Nestor Enrique Ruiz R.,
 Ingeniero Mecánico
 CIP 28866

El consumo de GLP de los distintos equipos estará proporcionado a condiciones normales (101,324 kPa y 283,15 K (n)) y, estos son:

Estimado de la Máxima Demanda del Consumo de GLP

Calderos
 Caldera de 50 BHP

$Q_{trans} = 1'673,750 \text{ BTU/h} * 0.000293 = 794.8 \text{ kW} \dots\dots\dots (A)$

Calentadores para Agua

Se considera suministro de agua caliente a las áreas de Hospitalización, consultorios y otras áreas consideradas, habiendo en total 122 camas.
 El volumen necesario de almacenamiento de agua caliente según el Reglamento Nacional de Edificaciones es de:



[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770
 CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21346625

Handwritten text at the top left, possibly a date or reference number.

Handwritten text in the upper left quadrant, possibly a name or title.

Handwritten text in the middle left section, possibly a date or reference.

Handwritten text in the lower left quadrant, possibly a name or title.

Handwritten text at the bottom left, possibly a date or reference.



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005052

250 litro x 51 camas = 12,750 l/d
día x cama

130 litro x 16 consultorios = 2,080 l/d
día x consultorio

Consumo en otras áreas
(estimado de sanitarias) = 5,150 l/d

Tenemos una dotación de Agua Caliente = 19,980 l/d.

DR. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

De acuerdo al Reglamento Nacional de Edificaciones, la capacidad horaria del equipo de producción de agua caliente en relación con la dotación en litros debe ser de una a seis. Es decir, la capacidad horaria debe ser de:

$$\frac{19980 \text{ l/d}}{6} = 3330 \text{ l/h} = 14.66 \text{ GPM}$$

CONFORME

Para el presente proyecto consideramos una producción de agua caliente 14.66 gpm. Por lo tanto, con una diferencia de temperatura de 72°F (40°C) sobre el agua fría.

La capacidad del calentador de agua debe ser:



$$Q = m \cdot c \cdot \Delta t$$



MANUEL BONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

En donde:

Q = Capacidad del calentador de agua en BTU/h.

m = Flujo de agua a través del calentador en lb/h.

m = 3330 l/h * 0.75 = 2,497 lb/h.

c = Constante = 1 BTU/lb °F.

Δt = Diferencia de temperatura entre salida y entrada del agua al calentador.

$$= 140^\circ\text{F} - 68^\circ\text{F} = 72^\circ\text{F}.$$
$$(60^\circ\text{C} - 20^\circ\text{C} = 40^\circ\text{C}).$$

Vestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866

Luego de realizar los calculos: **Q = 179,820 BTU/h** (B)

Área de Cocina

- Cocina 6 hornillas +horno 590,000 BTU/h
- Plancha Lisa 30,000 BTU/h
- Freidora 65,000 BTU/h
- Marmiota 15 lt 60,000 BTU/h
- Marmiota 35 lt 90,000 BTU/h
- Cocina 4 hornillas +horno 360,000 BTU/h

EDWARD CERÓN TORRES
JEFE DE PROYECTO
CIP N° 61770

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 27946429



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

Consumo Total 1,195,000 BTU/h

005051

Estimado de la máxima demanda de GLP:

- Caldero 1'673,750 BTU/h
- Calentador de agua 179,820 BTU/h
- Cocina 1 195,000 BTU/h

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5770
 JEFE DE SUPERVISIÓN

Total Máxima Demanda 3'048,570 BTU/h

Factor de demanda: 0.50

Demanda Simultánea Total = 1'524,285 BTU/h

CONFORME

Cálculo del Volumen del Tanque de Almacenamiento

Promedio de BTU/h por galón de GLP: 91,400 BTU/gal

Galones de GLP por hora: 16.67 gal/h

Consumo en 12 horas/día: 200.12 gal/d

Autonomía de 10 días: 2001.25 gal

Selección de tanque de GLP: 2,500 gal

MANUEL DONATO GARCÍA JAVE
 ING. MECÁNICO-ELECTRICISTA
 REG. CIP N° 69138

Demanda Simultánea Total = 1'524,285 BTU/h

Nestor Enrique Ruiz R.,
 Ingeniero Mecánico
 Reg. CIP 29866

Capacidad de Vaporización

De tabla ANEXO de capacidad de vaporización de tanques, se obtiene:

Para determinar la capacidad de vaporización, considerando 20% de volumen mínimo o de reposición del tanque, se requiere un tanque de 2500 gal. (Interpolando entre 1,000 gls y 5500 gls) se tiene una capacidad de vaporización de 1,668,912 mayor a la demanda simultánea requerida de **1'524,285 BTU/h** cuya capacidad es suficiente para cumplir con la demanda del hospital. Sin embargo, para determinar la capacidad del tanque se debe tener en cuenta la autonomía de abastecimiento del GLP con la cual se selecciona la capacidad del tanque

Por lo tanto, consideramos un tanque de capacidad comercial de **2,500 galones**, que garantiza la vaporización natural entre el 20% y 85% de la demanda máxima con 10% de factor de seguridad.



CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARÍA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 OMI N° 23946425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770

10/10/10

DA

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

005050

Tabla N° 4.- Cuadro de capacidad de Vaporización de Tanques

TANQUES INSTALADOS SOBRE SUPERFICIE O AEREOS
CAPACIDAD DE VAPORIZACIÓN NATURAL PARA USO INTERMITENTE BTU/h

[Handwritten Signature]

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

TANQUES INSTALADOS SOBRE SUPERFICIE O TECHOS							
CAPACIDAD DE VAPORIZACIÓN NATURAL PARA USO INTERMITENTE BTU/h							
%Vol. Líquido	Factor K	Capacidad Nominal de Tanque Cilíndrico Horizontal (Gal)					
		120	250	500	1000	5 500	10 000
60%	100	632,352	1,051,522	1,631,595	3,180,978	8,809,970	15,917,664
50%	90	569,116	946,370	1,468,436	2,862,881	7,928,973	14,325,897
40%	80	505,881	841,218	1,305,276	2,544,783	7,047,976	12,734,131
30%	70	442,646	736,065	1,142,117	2,226,685	6,166,979	11,142,365
20%	60	379,411	630,913	978,957	1,908,587	5,285,982	9,550,598
10%	45	284,558	473,185	734,218	1,431,440	3,964,486	7,162,949



NOTA: Tabla obtenida de la relación $Q = D * L * K$, (Método aproximado en función de la geometría del tanque);

Donde:

- Q: BTU/h;
- D: Diámetro exterior – (plg);
- L: Largo total – (plg);
- K: Constante para porcentaje de volumen de líquido en el recipiente.

[Handwritten Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Dimensionamiento de Tuberías

[Handwritten Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

Para el dimensionamiento de la red de distribución interna de GLP se toma en cuenta las capacidades y la ubicación de los diferentes equipos de combustión.

Toda la instalación está dimensionada para conducir el caudal requerido por los equipos y las ampliaciones futuras previstas, teniendo en cuenta las limitaciones en la pérdida de carga y velocidad.

CONFORME

Para el cálculo de caída de presión (Pérdida de Carga) se han usado las siguientes fórmulas:

- Para presiones mayores a 50 mbar(g) y menores a 4 bar(g) la fórmula de Renouard es:

$$P_A^2 - P_B^2 = 48,6 \times S \times L \times \frac{Q^{1.82}}{D^{4.82}}$$

Donde:

- (g) : Significa presión manométrica.
- P_A y P_B: Presión absoluta en ambos extremos del tramo [bar (A)].
- S : Densidad relativa del GLP (1.5).
- L : Longitud del tramo (m), incluyendo la longitud equivalente de los accesorios que la componen.

[Handwritten Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778
 CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 DNI N° 21546425



Q : Caudal (m³/h) a Condiciones Normales.
 D : Diámetro (mm).

- Para el cálculo de velocidad de circulación del fluido se usará la siguiente fórmula:

$$V = \frac{374 \times Q}{D^2 \times P}$$

Donde:

Q : Caudal (m³/h) a Condiciones Normales.
 P : Presión de cálculo [bar (A)].
 D : Diámetro interior de la tubería (mm).
 V : Velocidad lineal (m/s).

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 IEFEE DE SUPERVISIÓN

MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. O.P. N° 63128

La fórmula de Renouard es válida si se cumple las siguientes condiciones en simultáneo:

$$Q/D < 150$$

$$V < 20 \text{ m/s}$$

$$R = T (Q/D) < 2'000,000$$

CONFORME

Dónde: R: Número de Reynolds.

$$T = 72,000 \text{ (Para GLP).}$$

Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 R.P. CIP 29866

La presión máxima de alimentación a la red interna es de 2 bar (g), la cual será regulada a una presión media de distribución de 10 Psi (g).

Para determinar los diámetros nominales de la red de GLP (D), se ha considerado que las caídas de presión deben ser menores al 10% ($P_B = 0.9P_A$), en el tramo de aplicación respectivo (L), utilizando la ecuación de Renouard, comprobándose su validez aplicando las condiciones de Renouard.



Para efectos de cálculo, las cargas térmicas (BTU/h) se han convertido a m³/h (Poder Calorífico del GLP es 91,000 BTU/gal).

4. SISTEMA DE PETROLEO – BIODIESEL B5

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61779

A. Grupos Electrógenos:

Se ha considerado abastecimiento de petróleo para casos de emergencia para un grupo electrógeno de **700 kW** (100% de la carga de emergencia), y otra reserva para trabajar en Redundancia a futuro

Para determinar la capacidad del tanque de almacenamiento de Biodiesel B5, se ha considerado como criterio de cálculo el consumo de combustible de los equipos mencionados.

CONSORCIO CONSULTOR SAUL GARRIDO



CONSORCIO CONSULTOR SAUL GARRIDO RUC 20607759538

005548

Considerando que los equipos funcionarán durante 48 horas y con un factor de servicio determinado:

Consumo del GE de 700 kW = 172 l/h (45.44 gal/h) y Factor de Servicio = 0.65

Consumo = 45.44 gal/h x 0.65 = **29.50 gal/h**.

La máxima demanda de consumo de Petróleo es de **29.5 gal/h**

Para un respaldo por 5 días h, operación de 12 h/día se tiene:

C: 29.50 gal/h x 12 h x 5 = **1770 gal**.

Jorge
DR. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

B. Calderos: 50 BHP

Se ha considerado abastecimiento de petróleo para dos calderos de 50 BHP c/u, para trabajo alternado

Considerando que los equipos funcionarán durante 12 h/día y con un factor de servicio determinado y autonomía para 3 días, se tiene

Consumo de una caldera de 50 BHP = 17.0 gal/h y un Factor de Servicio de 0.7

Consumo = 17.0 gal/h x 12 horas x 3 x 0.7 = **714 gal**

CONSUMO TOTAL DE DB5: (A+B): 2,484 gal

Tomamos la capacidad del tanque de almacenamiento de **2,500 gal**

Manuel
MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 03108

CONFORME

Vestor Enrique Ruiz P.
Vestor Enrique Ruiz P.
Ingeniero Mecánico
Reg. CIP 29866

Para el presente proyecto esta capacidad será dada por un (1) tanque de almacenamiento de una capacidad de **2,500 galones** y un (1) tanque de diario de una capacidad de almacenamiento de **150 galones** para la Sala de Calderas, y un (1) tanque de diario de una capacidad de almacenamiento de **200 galones** para la Sala de Grupos Electrónicos.

Procedimientos de Cálculos Hidráulicos

Diámetros de Tuberías – (Descarga, Succión y Retorno)

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61779

Considerando la capacidad total del tanque de servicio de 200.0 gal, a ser llenado en 15 minutos tenemos un caudal de 21.43 gpm (0.84x10⁻³ m³/s).

Para una velocidad de 2.0 m/s (recomendada para el flujo de combustibles líquidos), el diámetro mínimo que cumple será:

$$Di = 10^3 \sqrt{\frac{4 \cdot Q}{\pi \cdot V}} = 10^3 \sqrt{\frac{4 \times 0.84 \times 10^{-3}}{3.1416 \times 2.0}} = 23.50 \text{ mm}$$

Donde: Q: Caudal en m³/s.



CONSORCIO CONSULTOR SAUL GARRIDO

Maria Luisa
M.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21986229



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

005047

V: Velocidad del fluido (m/s).

Di: Diámetro interno (mm).

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION

Para la presente instalación escogeremos un valor conservador para la tubería de alimentación a los tanques de servicios de **1 1/4" Ø (Di = 35.08 mm)**.

Fórmula de Pérdida por Fricción:

Las pérdidas por fricción en la tubería pueden determinarse sobre la base de la fórmula de Darcy y el Diagrama de Moody (En Sistema Internacional (SI)):

$$h_f = \frac{f \cdot L \cdot V^2}{2 \cdot g \cdot D}$$

$$h_s = \frac{k_{equi} \cdot V^2}{2 \cdot g}$$

$$h_{total} = h_f + h_s$$

$$H_{bomba} = h_{total} + z + \frac{V^2}{2 \cdot g}$$

CONFORME

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 60138

Donde:

- h_f : Pérdidas de carga primaria por fricción (m).
- h_s : Pérdidas de carga secundaria por fricción (m).
- z : Altura gravimétrica de 2.8 metros.
- h_{total} : Pérdidas de carga total por fricción (m).
- V: Velocidad media del flujo (m/s).
- D: Diámetro interno (m).
- f: Coeficiente de fricción.
- ρ : Densidad del fluido (kg/m³).
- g : Aceleración de la gravedad (m/s²).



[Signature]
Néstor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

5. TRANSPORTE VERTICAL

La capacidad de los ascensores se ha determinado en función de la cantidad de personas que deben ser evacuadas en un tiempo determinado.

CÁLCULO DE NÚMERO DE ASCENSORES

Comprende la determinación de ascensores de acuerdo al uso y capacidad

5.1 Ascensor de Pasajeros

- Tipo de uso : Hospitalario

[Signature]
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61779

CONSORCIO CONSULTOR SAUL GARRIDO



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

• Usuarios del ascensor :

- Personal Medico
- Funcionario Público
- Trabajadores
- Pacientes
- Visitas

005046

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

- Número de camas del Hospital : 51
- Transporte Vertical : 3 pisos
- Altura de recorrido del ascensor (h) : 13.75 m
- N° estimado de ascensores : 2
- Pisos de servicio de cada ascensor : pares e impares
- Capacidad estimada del ascensor : 13 personas
- Cantidad estimada de uso personas en el hospital :
- Número de visitantes por cama para hospitales : 4
- Número de camas : 51
- Número de ocupantes en total (PT) : 204

CONFORME

• Capacidad de transporte

- Tiempo de transporte por ascensor : 5 min = 300 s
- Cantidad a transportar (15% PT) @ 5 min : 31 personas
- Velocidad de transporte : 1.0 m/s
- N° de paradas : 3
- Intervalo por piso : 15 s
- Tiempo de transporte (3x15 s+2x13.75m/1.0 m/s): 72.5 s
- Capacidad de transporte (300 s) (13 personas)/72.5s: 53.8 personas

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

• Cálculo del N° de ascensores

- Número de ascensores:
 (N° de personas a transportar @ 5 min/Capacidad de transporte) =
 31 personas/53.8 personas = 0.58 ascensores
- Número de ascensores seleccionados : 2 unidades



[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

Características técnicas del ascensor:

- Capacidad comercial del Ascensor : 18 pasajeros
- Capacidad requerida del Ascensor : 1350 kg (mín.)
- Apertura de la puerta (mínima) : 1.10 m
- Dimensiones del Hueco : 4.70 x 3.00 m
- Dimensiones de la cabina : 2.10x1.60x2.40
- Cuarto de máquina dúplex : c/maquinas
- Profundidad del Foso (PIT) : 1.4 m (mín.)
- R.L.S. : 3.8m
- Nivelación automática por sistema de frecuencia variable
- Operación automática colectiva
- Sistema de tracción por cables, poleas y contrapeso, funcionamiento silencioso
- Motores eléctricos sin engranajes de imanes permanentes
- Motor de potencia aprox.de 11kw 3f, 380/220V, 60 Hz
- Tablero de mando y Control con microprocesadores
- Dispositivo limitador de carga.
- Seguridad de los motores por sobre temperatura y por falla de fase.

[Signature]
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

CONSORCIO CONSULTOR SAUL GARRIDO

Handwritten notes in the top left corner, including a date and some illegible text.

Handwritten notes in the middle left section, including a date and some illegible text.

Handwritten notes in the bottom left section, including a date and some illegible text.



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

005045

5.2 Ascensor Monta camillas

- Tipo de uso : Hospitalario
- Usuarios del ascensor :
 - Personal Medico
 - Camillas
 - Pacientes
 - Sillas de Ruedas
- Número de camas del Hospital : 51
- Transporte Vertical : 3 pisos
- Altura de recorrido del ascensor (h) : 13.75 m

[Signature]
 DRO. DAVID HECTOR TORRES PUENTE
 CIP 18776
 JEFE DE SUPERVISIÓN

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69128

De acuerdo a normas considerando la capacidad mínima de monta camias para hospitales y la distribución arquitectónica se ha determinado lo siguiente:

- N° de Monta camillas : 01
- Capacidad monta camillas (24 personas) : 1800 Kg
- Apertura de la puerta (mínima) : 1200 cm
- Velocidad : 1 m/s
- Dimensiones del Hueco : 3.60 x 2.80 m
- Dimensiones de la cabina : 2.10 x 2.70 x 2.20m
- Tipo de ascensor : con maquinas
- Profundidad del Foso (PIT) : 1.50 m (min)
- R.L.S. : 3.80m
- Nivelación automática por sistema de frecuencia variable
- Operación automática colectiva
- Sistema de tracción por cables, poleas y contrapeso, de funcionamiento silencioso
- Motores eléctricos sin engranajes de imanes permanentes
- Motor de potencia aprox. 15 kw 3f, 380/220V, 60 Hz
- Tablero de mando y control con microprocesadores
- Dispositivo limitador de carga.
- Seguridad de los motores por sobre temperatura y por falla de fase.

CONFORME

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

5.3 Montacargas

- Tipo de uso : Hospital
- Utilización del ascensor :
 - Transporte de Carga
 - Materiales
 - Equipos
 - Personal de servicio
- Número de camas del Hospital : 51
- Transporte Vertical : 3 pisos

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Selección de Montacargas:

Se selecciona un equipo Montacargas para uso exclusivo de transporte de carga y de personal de servicio, con menores exigencias de comodidad que las requeridas para los ascensores de uso público:

- N° de montacargas : 01
- Velocidad de Montacargas : 0.5 m/s
- Número de paradas : 3

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

- Recorrido del montacargas : 13.75 m
- Capacidad del montacargas : 1,500 kg (20p.)
- Apertura de la puerta (mínima) : 1.10 m
- Dimensiones mínimas de la cabina : 2.10x2.7x2.4 m / 2.00x2.60x2.25 m
- Dimensiones del hueco : 3.60 x 2.80 m / 3.60 x 2.90 m
- Cuarto de máquina : con c/maquinas
- Profundidad del Foso (PIT) : 1.5 m (Mín.)
- RLS : 3.80m
- Motores eléctricos sin engranajes de imanes permanentes
- Motor de potencia aprox de 11kw 3f 380/220v 60 Hz
- Tablero de Mando y Control con microprocesadores
- Nivelación automática por sistema de frecuencia variable
- Operación autónoma simple.
- Sistema de tracción por cables, poleas y contrapeso, funcionamiento silencioso
- Dispositivo limitador de carga.
- Seguridad de los motores por sobre temperatura y por falla de fase.

005044

DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

CONFORME

El Reglamento Nacional de Edificaciones establece medidas mínimas de ancho de cabina para ascensores operando en edificios públicos de 1.20m, por lo que la selección de ascensores públicos y monta camilla deberán cumplir, también con esta exigencia

Nota: Las dimensiones dadas son referenciales. Estas deberán ser definidas por el Contratista de acuerdo a las características del fabricante.

6. SISTEMA DE VAPOR Y RETORNO DE CONDENSADO

Para el presente Proyecto se plantea instalar una red de vapor desde dos calderas con capacidad de vapor que cubra con los requerimientos de los equipos de las áreas de Cocina, Lavandería, Autoclaves y Esterilizadores. Las calderas trabajarán: una en servicio y el otro en stand by (según el Programa de Producción y Mantenimiento).

La red de Vapor se considera desde el Cabezal o Manifold de Distribución de Vapor al servicio de Lavandería y a las Estaciones de Reducción de Presión de Vapor, Unidad Esterilización y Cocina

Se tendrá en cuenta la red de Condensado de Vapor desde los Calentadores, Lavandería, Unidad Esterilización, Estaciones de Reducción de Presión de Vapor y cabezal hasta el tanque de condensado.

Las redes de vapor y condensado deben aislarse térmicamente.

• Cálculo de la Demanda de Vapor de Agua

Área de Lavandería

Lavadora Centrifuga Tipo Barrera Sanitaria de 27 kg (2 unid)	: 186 kg/h
Secadora a Vapor Industrial de 13 kg (2 unid)	: 120 kg/h
Planchadora de Rodillo Calandria (1 unid)	: 171 kg/h
Consumo Total	: 477 kg/h

Área de Unidad de Esterilización

Esterilizador doble puerta Barrera Sanitaria (1 Unid)	: 45 kg/h
Esterilizador doble puerta Barrera Sanitaria (1 Unid)	: 45 kg/h

Hector Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866



EDWARD CERÓN TORRES
JEFE DE PROYECTO
CIP N° 69138

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

005043

Consumo Total Est. : 90 kg/h

Área de Unidad de Autoclave

Consumo de vapor del Autoclave:
 Dos autoclaves

94 kg/h

DR. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN

Demanda de vapor

Servicio	Consumo Kg/h	factor	Total kg/h
Esterilizacion	90	0.8	72.00
Lavanderia	477	0.8	381.60
Autoclave	94	0.8	75.20
Demanda de vapor			528.80 kg/h

CONFORME

Se asume que la caldera opera a una presión de servicio de 100 Psi (g), el agua de alimentación ingresa a la caldera a 50°C (condición de líquido subenfriado) y sale en forma de vapor a 170°C; para estas condiciones se determina la variación de entalpias mediante tablas termodinámicas para determinar el calor transferido para obtener la demanda máxima de vapor para:

$$M_{\text{vapor}} = 528.80 \text{ kg/h} \times 2.2 \text{ lb/kg} = 1,163.36 \text{ lb/h}$$

$$Q_{\text{trans}} = m_{\text{vapor}} \times [(h_g - h_f) + C_{pm}(T_2 - T_1)]$$

Donde:

- Q_{trans}: Calor transferido (BTU/h).
- M_{vapor}: Flujo másico (lb/h) = 818.4 lb/h
- C_{pm}: Calor específico promedio del agua (BTU/lb °F).
- T₁: Temperatura - 338°F.
- T₂: Temperatura - 120°F.
- h_g: Entalpia de Vapor Saturado a 338°F, es 1,189.7 BTU/lb.
- h_f: Entalpia de Líquido Saturado a 338°F, es 318.48 BTU/lb.

MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69136

Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

$$Q_{\text{trans}} = 1,163.36 \text{ lb/h} [(1,189.7 - 318.48) \text{ BTU/lb} + 1 \text{ BTU/lb}^\circ\text{F} \cdot (338 - 120)^\circ\text{F}]$$

$$Q_{\text{trans}} = 1,163.36 \text{ lb/h} \cdot (871.22 + 218) \text{ BTU/lb}$$

$$Q_{\text{trans}} = 1,267,155 \text{ BTU/h}$$

$$Q_{\text{trans}} = \frac{1,267,155 \text{ BTU/h}}{33,479 \text{ BTU/h/BHP}}$$

$$Q_{\text{trans}} = 37.55 \text{ BHP}$$



EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61777

Capacidad considerando 15% perdida (Q₃):

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARRAJO MUÑOZ
 REPRESENTANTE COMÚN
 RUC N° 21546425



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

$$Q_3 = 37.55 \text{ BHP} * 1.15 = 43.18 \text{ BHP}$$

005042

Funcionamiento de la caldera al 85% se tiene

$$Q_3 = 43.18 \text{ BHP} / 0.85 = 50.80 \text{ BHP}$$

ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

La capacidad comercial de la caldera será **50 BHP**, se requieren dos (02) unidades iguales para una operación alterna.

Dimensionamiento de Tuberías Sistema de Vapor

CONFORME

Para el dimensionamiento de la red de distribución de vapor se ha tomado en cuenta las capacidades y la ubicación de los diferentes equipos que trabajan con vapor.

El vapor generado por la caldera alimentará al Área de Lavandería a una presión de 100 PSIG, lo cual no habría necesidad de una estación de reducción.

Área de Unidad de Esterilización a una presión de 40-50 PSIG; que servirá también para la autoclave de residuos solidos, para ambas áreas se contarán con Estacion Reductora de Presión de 100-50 PSI a su presión de trabajo.

Mediante la siguiente expresión se determinó los diámetros de la red de vapor de agua, considerando una velocidad máxima de flujo entre 1200 y 1800 m/min para evitar ruidos y erosiones en las tuberías (según Normas).

$$d = \sqrt{\frac{4 \times 2.4 \times Q \times V_s}{\pi \times V}}$$

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

Descripción:

d: Diámetro nominal de la tubería (pulg).

Q: Gasto de Vapor (lb/h).

Vs: Volumen Específico (ft³/lb).

V: Velocidad del flujo de vapor (ft/min).



Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866

Se tomó en consideración que las pérdidas en los diferentes niveles de presión de trabajo sean limitadas al 10% de la presión de trabajo.

Se determinó las pérdidas de cada tramo mediante el Nomograma del vapor, según la presión de trabajo, considerando la ruta más crítica.

$$\Delta P = FC \times \Delta P_{100} \times L$$

Descripción:

ΔP : Caída de Presión por tramo (PSIG).

FC: Facto de Corrección.

EDWARD CERON TORRES
JEFE DE PROYECTO
CIP N° 61770
CONSORCIO CONSULTOR SAUL GARRIDO



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005041

ΔP100: Caída de presión por 100 pies.
L: Longitud del tramo (pies).

CALCULO DE CAIDA DE PRESION

Perdidas de presión del cabecero a la estación reductora en cada servicio -

RED DE VAPOR

ING. DAVID HECTOR TORRES PUENTE
CIP 13776
JEFE DE SUPERVISIÓN

SERVICIO	Presión de vapor kg/cm2	Flujo de vapor kg/h	Long m	diam pulg	diam mm	Velocidad m/s	DP/100m Kg/cm2	DP Tramo Kg/cm2	DP max Kg/cm2
Lavanderia	8	477	140	2"	50	14.0	0.25	0.350	0.400
Esterilización	4 a est	84	160	1 1/4"	32	5.8	0.07	0.112	0.200
Autoclave	4 a res	75.2	110	1 1/4"	32	8.0	0.35	0.185	0.200

Determinación de la electrobomba

Mediante la siguiente fórmula se determina las capacidades de las electrobombas.

$$Pot_{min} = \frac{\rho \cdot g \cdot H_{bomba} \cdot Q}{n_{electrom}}$$

Donde:

- Q : Caudal (m3/s).
- $n_{electrom}$: Eficiencia de la electrobomba.
- ρ : Densidad del fluido (kg/m3).
- g : Aceleración de la gravedad (m/s2)

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

Nestor Enrique Ruiz P.
Ingeniero Mecánico
Reg. CIP 29866

Capacidades de Electrobombas

Mediante la aplicación de fórmula se determina la capacidad de la electrobomba para las calderas.

$$HP = \frac{8.33 \times Q \times TDH \times G_e}{33000 \times n}$$

Donde:

- Operación: intermitente
- Temperatura: 77°C (170°F)
- Capacidad: para caldera de 80 BHP: Q = 5.5 gpm
- Gravedad específica del agua: 1.0
- Presión de trabajo:
 - Pw = 150 psi
- Presión de descarga: P2
 - P2 = 1.25*Pw

CONFORME

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

005040

- P2 = 187 psi = 431.9 pie
- Presión de succión: P1
 - P1 = 14.7 psi (presión atmosférica)
 - P1 = 14.7 x 2.31 = 34.0 pie

Perdidas de succión: Hfs = 0.66 pie (tubería 3 pie, válvula, filtro, codo)
 Perdidas por fricción: Hfs = 0.43 pie (tubería 10 pie, válvula, codos, unión)
 Altura de nivel de abastecimiento de agua Z = 2 pie
 Altura total dinámica de descarga, TDH (pies)

$$TDH = (P2 - P1) + Z + hs + hd$$

$$TDH = (431.9 - 34.0) + 2 + 0.66 + 0.43$$

$$TDH = 400.99$$

$$HP = \frac{8.33 \times Q \times TDH \times Ge}{33000 \times n}$$

$$HP = \frac{8.33 \times 11.4 \text{ gpm} \times 400.99 \times 1.0}{33000 \times 0.5}$$

$$HP = 2.3 \text{ hp}$$

Efecto altura: 1.28

$$HPt = 2.3 \times 1.28 = 2.95 \text{ HP}$$


 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN



 MANUEL DONATO GARCIA JURE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Para el sistema de alimentación las calderas se considera tres electrobombas, de las cuales una o dos (2) electrobombas se encontrarán en servicio y la tercera en stand by, la potencia seleccionada para las bombas de agua será de 3 HP

7. CLIMATIZACIÓN: CALEFACCIÓN, AIRE ACONDICIONADO Y VENTILACIÓN MECÁNICA

CONFORME

Para la determinación de capacidades de los equipos de climatización se han definido las cargas térmicas que cada ambiente genera de acuerdo a sus características operativas y constructivas, se ha tomado como referencia el manual de ASHRAE para Clínicas y Hospitales.

El cálculo de las ganancias terminas de los ambientes y dimensionamiento de los equipos se realizarán en base a los siguientes parámetros:


- a. Condiciones Exteriores (SENAMHI)
- Verano
- | | |
|-----------------------------|--------|
| Temperatura de bulbo seco: | 30.3°C |
| Temperatura de bulbo húmedo | 24.7°C |




 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

- b. Condiciones Interiores: (Fuente HVAC Design Manual for Hospitals and Clinics ASHRAE)

- Sala de cirugía y Partos:
- | | |
|---|---------------|
| Temperatura de bulbo seco : | 73 °F (23 °C) |
| Humedad Relativa : | 55% |
| Movimiento mínimo del aire : | 20 Cambios/h |
| Renovación de aire exterior: | 100% |
| Relación de presión con área adyacente: | Positiva |


 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770
 CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 ONI N° 21546425



CONSORCIO CONSULTOR SAUL GARRIDO
RUC 20607759538

005039

• Esterilización:

Temperatura de bulbo seco: 73 °F (23 °C)
 Humedad Relativa: 50%
 Movimiento mínimo del aire: 12 Cambios/h
 Relación de presión con área adyacente: Positiva

• Aislado:

Temperatura de bulbo seco: 73 °F (23 °C)
 Humedad Relativa: 50%
 Movimiento mínimo del aire: 15 Cambios/h
 Renovación de aire exterior: 100%
 Relación de presión con área adyacente: Positiva/Negativa

• Rayos X, Ecografía:

Temperatura de bulbo seco: 73 °F (23 °C)
 Humedad Relativa: 50%
 Movimiento mínimo del aire: 6 Cambios/h
 Renovación de aire exterior: 2 Cambios/h
 Relación de presión con área adyacente: Positiva

• Laboratorio en general:

Temperatura de bulbo seco: 73 °F (23 °C)
 Humedad Relativa: 50%
 Movimiento mínimo del aire: 6 Cambios/h
 Renovación de aire exterior: 100%
 Relación de presión con área adyacente: Negativa

• Data Center y Comunicaciones

Temperatura de bulbo seco: 68°F (20 °C)
 Humedad Relativa: 50%
 Movimiento mínimo del aire: 4 Cambios/h
 Relación de presión con área adyacente: Positivo

c. Fluctuación:

Temperatura de bulbo seco: +/- 2°F
 Humedad relativa: +/- 5%

d. Iluminación:

Sala de partos y Cirugía: 65 W/m2
 En General: 10 W/m2

e. Coeficientes globales de transmisión

Ventanas Exteriores : 5.7 W/m2-°C
 Paredes Exteriores : 2.027 W/m2-°C
 Paredes Interiores : 2.027 W/m2-°C
 Piso al terreno : 1.306 W/m2-°C
 Entre piso c/FCR : 1.306 W/m2-°C
 Techo al sol : 1.306 W/m2-°C

ARQ. DAVID HECTOR TORRES PUNTE
 CAP. 6776
 JEFE DE SUPERVISIÓN

CONFORME

MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138



Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425



f. Ganancia por ocupantes

Sensible	:	80 W
Latente	:	80 W



g. Ventilación mecánica


Baños, Depósito, cuarto de limpieza	:	10 cambios/h.
Oficina y Otros	:	10 cambios/h.



CALCULÓ DE CARGA TÉRMICA

Las cargas térmicas para diferentes condiciones estacionales se obtendrán mediante software ELITE. El software busca de forma automática todas las cargas de enfriamiento y los factores de corrección necesarios para procesar las cargas, para lo cual se le ha suministrado los datos climáticos.

Los reportes detallarán la siguiente información: Datos generales del proyecto, cargas de zonas detalladas, resumen de cargas de las unidades de acondicionamiento de aire, caudal de aire de renovación, cargas totales del edificio, capacidad frigorífica, caudal de impulsión de aire, caudal de retorno de aire, condiciones de temperatura del aire de entrada y salida de los serpentines, etc.



El método de cálculo, es mediante el método (CLTD), descrito en el último manual de fundamentos de ASHRAE. Este método es bastante seguro debido a que calcula el efecto de retraso de la ganancia del calor radiante durante cada uno de las pasadas 24 horas para determinar la carga de enfriamiento actual.

Los reportes de carga térmica se encuentran en el Anexo A.



DIMENSIONAMIENTO DE TUBERÍAS DE AGUA HELADA

Para el dimensionamiento del diámetro de las tuberías de agua helada se empleó otra herramienta digital de cálculo el Software System Syzer de Bell & Gossett.



Los criterios que se tomaron en cuenta, fueron son los siguientes:
Por recomendación de ASHRAE, el rango de caída de presión debe estar entre 1 a 4 pies por cada 100 pies de tubería. La velocidad del fluido entre 0.6 a 2 m/s (1.5 a 6.5 pie/s).

DIMENSIONAMIENTO DE TUBERÍAS DE REFRIGERACIÓN

Las tuberías de distribución del sistema de refrigeración son de cobre tipo "L" sin costura, con especificaciones ASTM B88-41, con extremos para ser soldados con accesorios normalizados.



En los equipos convencionales, los diámetros de tubería están estandarizados son especificados por los propios fabricantes



Para el dimensionamiento de las tuberías de cobre del sistema de Refrigeración de Volumen Variable se utilizara el Software de Selección Xpress VRV, el contratista deberá simular las dimensiones de las tuberías de refrigeración con el proveedor del sistema VRF según las longitudes de tuberías en el plano.

CONSORCIO CONSULTOR SAUL GARRIDO



DIMENSIONAMIENTO DE DUCTOS

Para la realización del cálculo de los ductos de climatización y ventilación se han empleado los métodos de recuperación estática para grandes redes de ductos y el método de pérdida de fricción constante para el sistema de climatización y ventilación mecánica.

El parámetro de fricción para el sistema de climatización es:

- Aire Acondicionado: 0.10 "C.A/ 100 ft
- Ventilación Mecánica: 0.15"C.A/ 100 ft

Para el dimensionamiento se utilizó el programa duct sizer.



VENTILACIÓN MECÁNICA EN COCINA

Para el caudal de ventilación mecánica se utilizó lo indicado en el Reglamento de Edificaciones (RNE) Art. 9.1.1.1 Campana, Capítulo III.30 Norma EM 0.30 "Los sistemas de ductos crearan una velocidad de acarreo del aire en el sistema de extracción, de no menos de siete y medio metros por segundo y no más de once metros por segundo. La velocidad del aire a través de la cara de la campana será como mínimo de medio metro por segundo".



Debido al alto caudal que se genera por la extracción de grasa para las cocinas se ha considera un sistema de campana tipo compensada.

SISTEMA DE PRESURIZACIÓN DE ESCALERA

Se ha considerado como escalera presurizada aquella denominada como escape y se ha tomado en consideración la norma de la NFPA 101 en el capítulo referente a este tema.





El sistema consta de un inyector de aire centrífugo en la azotea. Se ha colocado una rejilla de descarga por sobrepresión con damper de regulación que permita mantener la presión en el interior de la escalera cuando las puertas estén cerradas.

Al producirse un incendio, éste deberá ser detectado por el sistema de protección contra incendios implementado en el edificio, enviando una señal que pondrá en operación los ventiladores de los sistemas de presurización de las escaleras de escape, los cuales inyectarán aire a los ductos de mampostería previstos en el edificio y que contarán con rejillas de descarga de aire al nivel de cada uno de los pisos, logrando así, presurizar la escalera y evitando el ingreso de humo producto del siniestro.

La diferencia de presión mínima a mantenerse en la escalera, según la norma NFPA 92 A, para evitar el ingreso de humos, es de 0.05 pulgadas de columna de agua. Esta presión positiva será suficiente para evitar que el humo producido por el incendio ingrese a las escaleras de escape a través de las puertas de escape de cada uno de los pisos.

Por otro lado, este valor de la presión positiva ha sido determinado, teniendo presente que no deberá representar una resistencia que dificulte la apertura rápida de las puertas de escape de cada uno de los pisos.



La norma NFPA 92A, establece que la fuerza requerida para la apertura de puertas no deberá

000000

000000

000000

000000



CONSORCIO CONSULTOR SAUL GARRIDO

RUC 20607759538

005036

superar las 30 lb-f.

En cada una de las escaleras de escape, se instalarán sensores / transmisores de la presión diferencial existente en ellas y comandarán a los variadores de frecuencia de los respectivos motores de los ventiladores, regulando la velocidad de rotación de los mismos, de tal modo que se mantenga la presión estática de 0.05" de columna de agua.


ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

CONFORME





MANUEL DONATO GARCIA JAVE
ING. MECÁNICO-ELECTRICISTA
REG. CIP N° 69138


Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARÍA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI/N° 21546425


EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61770

Handwritten text at the top left of the page.

Handwritten text in the upper middle section of the page.

Handwritten text in the middle left section of the page.

CONFIDENTIAL COMPANY PROPERTY - RIGHT TO

CONFIDENTIAL COMPANY PROPERTY - RIGHT TO
CONFIDENTIAL COMPANY PROPERTY - RIGHT TO

CONFIDENTIAL COMPANY PROPERTY - RIGHT TO
CONFIDENTIAL COMPANY PROPERTY - RIGHT TO

David

005035

ARQ. DAVID HECTOR TORRES PUENTE

Chvac - Full Commercial HVAC Loads Calculation Program
Elite Software Development
College Station, TX 77845



CAP. 5776
JEFE DE SUPERVISIÓN

Elite Software Development, Inc.
Hospital Sagaro
Page 1

General Project Data Input

General Project Information

Project file name: D:\Proyectos\Nestor Ruiz\Hospital Sagaro\0. Anexo\0.1 Aire Acondicionado\Hospital Sagaro prueba.CHV

Project title: Hospital Sagaro

Project date: jueves, 30 de Setiembre de 2021

Project location: TUMBES, TUMBES, PERU

Barometric pressure: 1010.387 mbar

Altitude: 0 meters

Latitude: -3 Degrees

Mean daily temperature range: 9 Degrees

Starting & ending time for HVAC load calculations: 1am - 12am

Number of unique zones in this project: 246

Building Default Values

Calculations performed: Both heating and cooling loads

Lighting requirements: 10.00 Watts per square meter

Equipment requirements: 30.00 Watts per square meter

People sensible load multiplier: 80 Watts per person

People latent load multiplier: 80 Watts per person

Zone sensible safety factor: 5 %

Zone latent safety factor: 5 %

Zone heating safety factor: 8 %

People diversity factor: 100 %

Lighting profile number: 1

Equipment profile number: 1

People profile number: 1

Building default ceiling height: 3.0 meters

Building default wall height: 4.0 meters

CONFORME

Internal Operating Load Profiles (C = 100)

	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	0	0	0	0	0	0	C	C	C	C	C	C	C	C	C	C	C	C	C	0	0	0	0	0
2	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
3	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
4	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
5	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
7	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
8	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
9	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
10	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C



Manuel

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

Nestor Enrique Ruiz P.

Nestor Enrique Ruiz P.
Ingeniero Mecánico
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

Maria Luisa

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMUN
DNI N° 21546425

Edward Cerón

EDWARD CERÓN TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

005034

Juan
ARQ. DAVID HECTOR TORRES PUENTE

CAP. 5776

JEFE DE SUPERVISION

Elite Software Development, Inc.

Hospital Sagaro

Page 2

Chvac - Full Commercial HVAC Loads Calculation Program
Elite Software Development
College Station, TX 77845



General Project Data Input (cont'd)

Building-Level Design Conditions

Design Month	Outdoor Dry Bulb	Outdoor Wet Bulb	Indoor Rel.Hum	Indoor Dry Bulb	Grams Diff	In/Outdoor Correction
January	30	24	50%	23	7.64	-1
February	30	24	50%	23	7.33	-1
March	30	24	50%	23	8.28	-1
April	30	25	50%	23	8.60	-1
May	30	25	50%	23	8.53	-2
June	28	23	50%	23	6.89	-3
July	27	22	50%	23	5.76	-5
August	26	21	50%	23	5.32	-6
September	26	22	50%	23	5.93	-5
October	27	22	50%	23	6.30	-4
November	28	23	50%	23	6.92	-3
December	28	23	50%	23	6.92	-3
Winter	18			21		

Master Roofs

Roof No.	ASHRAE Roof#	Roof U-Fac	Dark Color	Susp. Ceil
1	1	2.210	No	Si

Master Walls

Wall No.	ASHRAE Group	Wall U-Fac	Wall Color
1	B	2.000	M

Master Partitions

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
1	2.360	4	8
2	2.210	4	8
3	2.360	4	5
4	2.210	4	5

CONFORME

Master Glass

Glass No.	Summer U-Factor	Winter U-Factor	Glass Shd.Coef.	Interior Shading	Interior Shd.Coef
1	5.700	5.800	0.950	1	0.700

Nestor Ruiz
Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866

Mandel Garcia
MANDEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

Edward Cerón
EDWARD CERÓN TORRES
JEFE DE PROYECTO
C.I.P. N° 61778



000000

Handwritten notes and stamps at the top center, including a circular stamp.

Handwritten text on the left side of the page.

Handwritten text at the bottom left of the page.

Handwritten text at the bottom center of the page.

Handwritten text at the bottom left of the page.

Handwritten text at the bottom center of the page.

Handwritten text at the bottom right of the page.

005033

ARQ. DAVID HECTOR TORRES PUENTE

CAP. 5776

JEFE DE SUPERVISIÓN

Elite Software Development, Inc.

Hospital Sagaro

Page 3

Chvac - Full Commercial HVAC Loads Calculation Program
Elite Software Development
College Station, TX 77845



Building Summary Loads

Building peaks in April at 3pm.

Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	2,131	18,301	3.73	0	100,947	100,947	6.87
Wall	1,646	11,862	2.42	0	20,765	20,765	1.41
Glass	341	7,134	1.46	0	74,943	74,943	5.10
Floor Slab	0	0	0.00	0	0	0	0.00
Skin Loads		37,297	7.61	0	196,655	196,655	13.37
Lighting	59,005	0	0.00	0	61,955	61,955	4.21
Equipment	161,006	0	0.00	0	169,056	169,056	11.50
People	1,225	0	0.00	89,859	98,792	188,652	12.83
Partition	20,770	401,835	81.98	0	195,336	195,336	13.28
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	16,562	0	0.00	450,606	142,595	593,201	40.34
Heat. Vent.	12,206	51,035	10.41	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	0	0	0.00
Blow-Thru Fan	0	0	0.00	0	10,465	10,465	0.71
Reserve Cap.	0	0	0.00	0	41,780	41,780	2.84
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	7,133	7,133	0.49
Return Duct	0	0	0.00	0	6,168	6,168	0.42
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		490,167	100.00	540,465	929,937	1,470,401	100.00

Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation	51,035	10.41	450,606	142,595	593,201	40.34
Infiltration	0	0.00	0	0	0	0.00
Pretreated Air	0	0.00	0	0	0	0.00
Zone Loads	439,132	89.59	89,859	763,575	853,434	58.04
Plenum Loads	0	0.00	0	0	0	0.00
Fan & Duct Loads	0	0.00	0	23,767	23,767	1.62
Building Totals	490,166	100.00	540,465	929,937	1,470,402	100.00

Check Figures

Total Building Supply Air (based on a 11° TD):	57,991 L/s
Total Building Vent. Air (28.56% of Supply):	16,562 L/s
Total Conditioned Air Space:	5,901 Sq.m
Supply Air Per Unit Area:	9.8282 L/s/Sq.m
Area Per Cooling Capacity:	4.0129 Sq.m/kW
Cooling Capacity Per Area:	0.2492 kW/Sq.m
Total Heating Required With Outside Air:	490.17 kW
Total Cooling With Outside Air:	1,470.40 kW



MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REC. CIP N° 69138

14.1126 Sq.m/Ton
0.0709 Tons/Sq.m

418.10 Tons

CONFORME

Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866



CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

Edward Cerón Torres
JEFE DE PROYECTO
C.I.P. N° 61778

005072

ARQ. DAVID MEDRANO TORRES PUEENTE
CAP. 6776
JEFE DE SUPERVISIÓN



Air Handler #1 - Fc - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
1	101 Entrevista Familiar 8am May	9	1,418	2,336	378	2/Hr	2/Hr
		6	84	174	0	15	15
		28	9.10	18.94	0	32	33
2	105 Estar Choferes 9am April	12	1,195	2,030	236	2/Hr	2/Hr
		5	71	151	0	20	20
		36	5.88	12.62	0	27	29
3	107 Triaje 7pm December	11	1,205	1,265	252	2/Hr	2/Hr
		3	71	94	0	18	18
		32	6.65	8.82	0	27	18
4	108 Espera 2pm May	109	5,370	8,314	898	2/Hr	2/Hr
		19	317	620	0	182	182
		327	2.91	5.68	0	120	119
5	109 Servicio Social 7pm May	10	998	1,393	189	2/Hr	2/Hr
		3	59	104	0	16	16
		29	6.20	10.94	0	22	20
6	110 Ref Cref 7pm December	9	1,119	1,194	189	2/Hr	2/Hr
		3	66	89	0	16	16
		28	7.03	9.47	0	25	17
7	111 Seguros 7pm December	10	1,251	1,268	189	2/Hr	2/Hr
		3	74	95	0	17	17
		31	7.10	9.10	0	28	18
8	113 Admisión 7pm December	13	1,342	1,573	126	2/Hr	2/Hr
		2	79	117	0	21	21
		38	6.24	9.24	0	30	22
9	113.1 Dispensación Y Expendio De Medicam 7am December	31	1,782	3,604	252	2/Hr	2/Hr
		3	105	269	0	52	52
		93	3.40	8.70	0	40	51
10	114 Topico De Intectables 5pm January	22	1,732	3,016	252	2/Hr	2/Hr
		3	102	225	0	36	36
		65	4.69	10.32	0	33	43
11	115 Topico Cirugia 5pm January	17	1,519	2,512	252	2/Hr	2/Hr
		3	90	187	0	29	29
		52	5.18	10.83	0	34	36
12	116 Sala De Rehidratación 9am April	15	1,350	2,544	252	2/Hr	2/Hr
		3	80	190	0	26	26
		46	5.21	12.40	0	30	36
13	117 Topico Medicina 9am April	16	1,386	2,734	252	2/Hr	2/Hr
		3	204	204	0	27	27
		48	5.08	12.67	0	31	39

MANUEL DONATO GARCIA JAME
ING. MECANICO-ELECTRICISTA
REC. CIP N° 69138

CONFORME



Nestor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
C.P.C. MARIA LUISA CARBAJO MUÑOZ
DNI N° 21348425

EDWARD CERON TORRES
JEFE DE PROYECTO

ARQ. DAMIAN TORRES PUEENTE
CAP. 5776
JEFE DE SUPERVISIÓN

Chvac - Full Commercial HVAC Loads Calculation Program
Elite Software Development
College Station, TX 77845



Elite Software Development, Inc.
Hospital Sagaro
Page 5

Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
14	118 Sala De Espera Para Reevaluación 9am April	62 9 186	4,271 252 4.06	4,392 328 5.28	425 0 0	2/Hr 104 96	2/Hr 104 63
15	119 Topico Pediatria 9am April	16 3 49	1,372 81 4.94	2,754 205 12.53	252 0 0	2/Hr 27 31	2/Hr 27 39
16	120 Terapia Medios Fisicos 7pm December	5 2 15	838 49 9.89	943 70 14.06	168 0 0	2/Hr 8 19	2/Hr 8 13
17	121 Topico Gineco Obstetricia 7pm December	16 3 48	1,526 90 5.66	1,633 122 7.66	252 0 0	2/Hr 27 34	2/Hr 27 23
18	126 Policia Nacional 7pm May	12 3 35	1,162 69 5.86	1,540 115 9.82	189 0 0	2/Hr 20 26	2/Hr 20 22
23	134 Estar De Perosnal De Guardia 5pm January	15 6 46	1,440 85 5.56	2,575 192 12.55	284 0 0	2/Hr 26 32	2/Hr 26 37
24	142 Secretaria 7pm December	11 3 32	1,322 78 7.29	1,306 97 9.10	189 0 0	2/Hr 18 30	2/Hr 18 19
25	143 Jefatura 7pm December	13 3 38	1,433 85 6.66	1,381 103 8.11	189 0 0	2/Hr 21 32	2/Hr 21 20
31	158 Oficina Coe 7pm December	13 3 38	1,405 83 6.64	1,365 102 8.15	189 0 0	2/Hr 21 31	2/Hr 21 19
32	161 Cocina Comedor 7am December	49 5 147	4,237 250 5.10	5,437 406 8.28	412 0 0	2/Hr 82 95	2/Hr 82 78
33	165 Habitación Gestante Adolescente 5pm January	15 2 44	1,380 81 5.54	2,420 181 12.28	168 0 0	2/Hr 25 31	2/Hr 25 35
34	166 Hobotación Gestante Sola 7am December	11 1 32	507 30 2.80	1,425 106 9.93	84 0 0	2/Hr 18 11	2/Hr 18 20

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

CONFORME



Nestor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP-29863

CONSORCIO CONSULTOR SAUL GARRIDO

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

005030

[Handwritten Signature]

ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

Elite Software Development, Inc.
Hospital Sagaro
Page 6

Chvac - Full Commercial HVAC Loads Calculation Program
Elite Software Development
College Station, TX 77845



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
35	169 Habitacupin Gestante Con Pareja 5pm January	16	1,143	2,616	168	2/Hr	2/Hr
		2	67	195	0	26	26
		47	4.35	12.59	0	26	37
36	170 Gimnasio Para Adultos Y Niños 3pm May	50	2,905	6,133	2,688	2/Hr	2/Hr
		8	171	457	0	84	84
		151	3.40	9.08	0	65	88
37	179 Jefatura 7pm May	16	1,420	1,629	189	2/Hr	2/Hr
		3	84	121	0	27	27
		48	5.27	7.64	0	32	23
38	180 Sala De Espera 2pm May	56	2,405	5,092	850	2/Hr	2/Hr
		18	142	380	0	94	94
		169	2.52	6.73	0	54	73
39	187 Sala De Fisioterapia 7pm December	34	2,490	2,475	282	2/Hr	2/Hr
		3	147	185	0	56	56
		101	4.37	5.50	0	56	35
40	188 Hidroterapia Medios Superiores 7pm December	19	2,894	2,248	168	2/Hr	2/Hr
		2	171	168	0	32	32
		57	8.95	8.78	0	65	32
41	192 Historias Clinicas 7pm December	29	2,324	1,831	63	2/Hr	2/Hr
		1	137	137	0	49	49
		88	4.68	4.66	0	52	26
42	193 Caja 7pm December	7	981	939	63	2/Hr	2/Hr
		1	58	70	0	11	11
		20	8.90	10.77	0	22	13
43	194 Admisión Y Citas 7pm December	14	1,486	1,659	126	2/Hr	2/Hr
		2	88	124	0	24	24
		43	6.18	8.71	0	33	24
44	196 Central De Vigilancia Y Seguridad 7am December	19	1,757	2,740	252	2/Hr	2/Hr
		4	104	204	0	32	32
		58	5.35	10.53	0	39	39
46	198 Almacen Especializado 7pm December	51	3,269	2,678	189	2/Hr	2/Hr
		3	193	200	0	85	85
		154	3.77	3.90	0	73	38
47	199 Dispensacion Y Expendio 7pm December	41	2,878	2,690	189	2/Hr	2/Hr
		3	170	201	0	68	68
		122	4.19	4.95	0	68	38

MANUEL DONATO GARCIA JUNE
ING. MECANICO ELECTRICISTA
REG. CIP. N° 69136

CONFORME



[Handwritten Signature]
Nestor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP. 28699

CONSORCIO CONSULTOR SAUL GARRIDO

[Handwritten Signature]
EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

Handwritten signature

ARG. DAVID HECTOR TORRES PUENTE



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
48	1100 Farmacovig Y Tecnovigi 7pm December	23	1,909	2,270	378	2/Hr	2/Hr
		6	113	169	0	38	38
		68	4.94	7.43	0	43	32
49	1101 Gestion De Programación 7pm December	13	1,379	1,358	189	2/Hr	2/Hr
		3	81	101	0	22	22
		39	6.26	7.79	0	31	19
50	1104 Jefatura Secretaria 7pm December	17	1,707	2,109	378	2/Hr	2/Hr
		6	101	157	0	28	28
		50	6.00	9.36	0	38	30
51	1107 Dosis Unitaria 7pm December	28	2,226	2,245	441	2/Hr	2/Hr
		7	131	167	0	47	47
		85	4.66	5.94	0	50	32
52	1108 Jefatura Secretaria 7pm December	15	1,568	2,025	378	2/Hr	2/Hr
		6	93	151	0	26	26
		46	6.05	9.87	0	35	29
53	1109 Sala De Ecografia General 7pm December	17	1,623	1,849	252	2/Hr	2/Hr
		3	96	138	0	28	28
		51	5.64	8.11	0	36	26
54	1113 Sala De Impresió 7pm December	22	2,047	2,407	189	2/Hr	2/Hr
		3	121	180	0	37	37
		66	5.49	8.16	0	46	34
55	1114 Comando 7pm December	6	886	1,202	63	2/Hr	2/Hr
		1	52	90	0	10	10
		18	8.72	14.95	0	20	17
56	1115 Sala De Radiologia Convencional 7pm December	20	1,740	2,793	168	2/Hr	2/Hr
		2	103	208	0	33	33
		59	5.27	10.68	0	39	40
57	1116 Recepción 7pm December	11	1,323	1,545	126	2/Hr	2/Hr
		2	78	115	0	18	18
		33	7.17	10.57	0	30	22
63	1128 Registro De Laboratorio 7pm December	6	857	870	63	2/Hr	2/Hr
		1	51	65	0	9	9
		17	8.88	11.39	0	19	12

Handwritten signature
MANUEL GONZALEZ GARCIA JAVE
ING. MECANICO ELECTRICISTA
REG. CIP N° 69138



CONFORME

Handwritten signature
Nestor Enrique Ruiz
Ingeniero Mecánico
CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
Handwritten signature
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

Handwritten signature
EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

00110

Handwritten scribbles and faint text at the top of the page.

Vertical handwritten text on the left side of the page.



Faint, illegible text at the bottom of the page, possibly bleed-through from the reverse side.

ARQ. EDUARDO GERON TORRES PUEBLO

CAP. 5776

JEFE DE SUPERVISIÓN

Elite Software Development, Inc.

Hospital Sagaro

Page 8

Chvac - Full Commercial HVAC Loads Calculation Program
Elite Software Development
College Station, TX 77845



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
64	1129 Toma De Muestras Sanguinea 7pm December	9 2 26	1,058 62 7.26	1,077 80 9.34	126 0 0	2/Hr 14 24	2/Hr 14 15
66	1135 Recepción De Muestras 7pm December	13 2 40	1,453 86 6.45	1,634 122 9.16	126 0 0	2/Hr 22 32	2/Hr 22 23
67	1136 Jefatura Secretaria 7pm December	17 6 50	1,619 96 5.69	2,066 154 9.17	378 0 0	2/Hr 28 36	2/Hr 28 29
70	1140 Hall 7pm December	102 12 305	5,251 310 3.04	4,839 361 3.55	1,008 0 0	2/Hr 170 117	2/Hr 170 69
72	1148 Ref Cref 7pm December	9 3 28	1,132 67 7.19	1,199 89 9.62	189 0 0	2/Hr 16 25	2/Hr 16 17
73	1150 Seguros 7pm December	12 3 36	1,298 77 6.39	1,308 98 8.13	189 0 0	2/Hr 20 29	2/Hr 20 19
74	1151 Servicio Social 7pm December	9 3 28	1,109 65 7.04	1,166 87 9.35	189 0 0	2/Hr 16 25	2/Hr 16 17
79	1160 Sala De Espera 7am January	376 150 1,129	16,042 947 2.52	28,610 2,134 5.67	7,088 0 0	2/Hr 627 359	2/Hr 627 408
80	1161 Psicoprofilaxis 7pm December	39 5 117	2,664 157 4.02	2,755 206 5.26	420 0 0	2/Hr 65 60	2/Hr 65 39
81	1162 Consultorio De Gineco Obstr 7pm December	15 3 45	1,631 96 6.42	1,517 113 7.54	252 0 0	2/Hr 25 36	2/Hr 25 22
82	1164 Consultorio De Gineco Obstr 7pm December	15 3 45	1,631 96 6.42	1,517 113 7.54	252 0 0	2/Hr 25 36	2/Hr 25 22
83	1166 Control Prenatal 7pm December	15 3 44	1,629 96 6.63	1,511 113 7.77	252 0 0	2/Hr 24 36	2/Hr 24 22

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138



CONFORME

Nestor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO

EDUARDO GERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
D.M. N° 2154822

005027



JEFE DE SUPERVISIÓN

Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg. Loss Htg.L/s L/s/Sqm	Sen. Gain Clg.L/s L/s/Sqm	Lat. Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
84	1173 Planificación Familiar 5pm January	15	1,358	2,601	252	2/Hr	2/Hr
		3	80	194	0	24	24
		44	5.49	13.29	0	30	37
85	1174 Sala De Estimulación Temprana 5pm January	19	1,552	2,784	252	2/Hr	2/Hr
		3	92	208	0	32	32
		58	4.72	10.70	0	35	40
86	1176 Consultorio De Pediatría 5pm January	15	1,423	2,633	252	2/Hr	2/Hr
		3	84	196	0	24	24
		44	5.76	13.45	0	32	38
87	1177 Consultorio De Pediatría 5pm January	15	1,423	2,633	252	2/Hr	2/Hr
		3	84	196	0	24	24
		44	5.76	13.45	0	32	38
88	1178 Consultorio De Crecimiento Y Desarr 5pm January	17	1,463	2,704	252	2/Hr	2/Hr
		3	86	202	0	29	29
		52	4.99	11.66	0	33	39
89	1179 Sala De Inmunizaciones 5pm January	15	1,384	2,629	252	2/Hr	2/Hr
		3	82	196	0	26	26
		46	5.34	12.82	0	31	38
90	1180 At Int Del Adulto Mayor 5pm January	15	1,391	2,633	252	2/Hr	2/Hr
		3	82	196	0	26	26
		46	5.37	12.83	0	31	38
91	1183 Cyp De Enferm 7pm March	16	1,392	1,590	252	2/Hr	2/Hr
		3	82	119	0	27	27
		49	5.04	7.28	0	31	23
92	1184 Cyp De Enf. No Trans 5pm January	15	1,358	2,601	252	2/Hr	2/Hr
		3	80	194	0	24	24
		44	5.49	13.29	0	30	37
93	1185 Triaje 5pm January	13	1,363	2,577	252	2/Hr	2/Hr
		3	80	192	0	22	22
		39	6.14	14.67	0	30	37
110	205.1 Estación De Obstetricia 3pm April	12	1,311	1,789	168	2/Hr	2/Hr
		2	77	133	0	21	21
		37	6.29	10.85	0	29	26

CONFORME

CONFORME

MANUEL DONATO GARCIA JIMENEZ
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138



Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Handwritten signature



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
112	211 Estar De Personal 3pm April	12 6 37	1,165 69 5.59	1,949 145 11.82	504 0 0	2/Hr 21 26	2/Hr 21 28
113	212 Control 3pm April	7 1 20	858 51 7.56	1,175 88 13.08	63 0 0	2/Hr 11 19	2/Hr 11 17
128	247 Estar De Personal 3pm April	14 7 42	1,559 92 6.57	2,317 173 12.35	588 0 0	2/Hr 23 35	2/Hr 23 33
129	249 Control 3pm April	5 1 15	722 43 8.70	1,017 76 15.48	84 0 0	2/Hr 8 16	2/Hr 8 15
130	250 Coordinación De Enfermeria 3pm April	12 6 36	1,179 70 5.75	2,019 151 12.44	378 0 0	2/Hr 20 26	2/Hr 20 29
131	251 Jefatura Secretaria 3pm April	16 2 48	1,428 84 5.30	2,346 175 11.01	126 0 0	2/Hr 27 32	2/Hr 27 33
132	252 Sala De Reuniones 3pm April	12 6 37	1,165 69 5.59	2,054 153 12.46	504 0 0	2/Hr 21 26	2/Hr 21 29
134	254 Jefatura 3pm April	11 3 34	1,149 68 6.06	1,719 128 11.45	189 0 0	2/Hr 19 26	2/Hr 19 25
140	269 Unidad De Logistica 2pm May	31 6 92	1,453 86 2.79	6,397 477 15.54	378 0 0	2/Hr 51 32	2/Hr 51 91
141	270 Unidad De Personal 2pm May	30 7 90	1,716 101 3.37	6,663 497 16.51	441 0 0	2/Hr 50 38	2/Hr 50 95
142	271 Unidad De Personal 2pm May	30 7 90	1,716 101 3.37	6,663 497 16.51	441 0 0	2/Hr 50 38	2/Hr 50 95
143	272 Secretaria 2pm May	25 6 74	1,559 92 3.76	4,806 358 14.63	378 0 0	2/Hr 41 35	2/Hr 41 69

Handwritten signature
MANUEL DONATO GARCIA LAINE
ING. MECANICO-ELECTRICISTA
REC. CIP N° 03128



CONFORME

Handwritten signature
Nestor Enrique Ruiz
Ingeniero Mecánico

CONSORCIO CONSULTOR SAUL GARRIDO

Handwritten signature
EDWARD CERON TORRES
JEFE DE PROYECTO
C.P. N° 81773

005025



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
144	273 Unidad De Gestion De La Calidad 2pm May	25 5 74	1,550 91 3.73	5,105 381 15.54	315 0 0	2/Hr 41 35	2/Hr 41 73
145	274 Secretaria 2pm May	15 3 45	1,312 77 5.16	3,505 261 17.43	189 0 0	2/Hr 25 29	2/Hr 25 50
146	275 Dirección General 2pm May	24 9 72	1,419 84 3.50	5,286 394 16.50	567 0 0	2/Hr 40 32	2/Hr 40 75
147	277 Unidad De Asesoría Jurídica 5pm January	10 3 29	811 48 5.04	2,147 160 16.86	189 0 0	2/Hr 16 18	2/Hr 16 31
148	279 Oficina De Planeamiento 5pm January	31 5 92	2,203 130 4.25	4,359 325 10.63	315 0 0	2/Hr 51 49	2/Hr 51 62
149	280 Unidad De Seguros 7pm December	27 5 80	2,215 131 4.88	2,697 201 7.51	315 0 0	2/Hr 45 50	2/Hr 45 39
150	281 Sala De Espera 7pm December	24 12 73	2,106 124 5.12	2,497 186 7.66	1,008 0 0	2/Hr 41 47	2/Hr 41 36
151	282 Tramite Documentario 7pm December	9 1 28	1,154 68 7.25	1,049 78 8.32	59 0 0	2/Hr 16 26	2/Hr 16 15
152	283 Sala De Usos Múltiples 7pm December	24 21 73	2,046 121 4.97	3,318 247 10.19	992 0 0	2/Hr 41 46	2/Hr 41 47
153	284 Epidemiología Y Salud Ocupacional 7pm December	37 12 110	2,658 157 4.28	3,945 294 8.02	1,008 0 0	2/Hr 61 59	2/Hr 61 56
154	291 Sala De Espera Centro Obstétrico 7pm December	48 30 145	3,801 224 4.66	5,084 379 7.87	2,520 0 0	2/Hr 80 85	2/Hr 80 73
156	194 Sala De Refracción 7pm December	26 4 79	2,112 125 4.72	2,270 169 6.41	336 0 0	2/Hr 47 47	2/Hr 47 32

Handwritten signature

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION

CONFORME

MANUEL DONATO GARCIA JAVIE
 ING. MECANICO ELECTRICISTA
 REC. CIP N° 03126

GOBIERNO DEL ESTADO DE GUERRERO
 SECRETARIA DE ESTUDIOS

EDUARDO CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
157	195 Sala De Ecografia Obstetrica 7pm December	16 3 47	1,559 92 5.83	1,491 111 7.04	252 0 0	2/Hr 26 35	2/Hr 26 21
158	197 Recepción Y Control 7pm December	12 3 35	1,472 87 7.56	1,403 105 9.10	252 0 0	2/Hr 19 33	2/Hr 19 20
160	2015 Sala De Electro Cardiografia 7pm December	14 3 43	1,458 86 6.06	1,425 106 7.48	252 0 0	2/Hr 24 33	2/Hr 24 20
161	2106 Sala De Holter Y Mapa 7pm December	11 3 34	1,252 74 6.60	1,293 96 8.61	252 0 0	2/Hr 19 28	2/Hr 19 18
162	2107 Sala De Espirometria 7pm December	12 3 35	1,295 76 6.48	1,320 98 8.35	252 0 0	2/Hr 20 29	2/Hr 20 19
167	2118 Jefatura 7pm December	12 3 36	1,306 77 6.43	1,312 98 8.16	189 0 0	2/Hr 20 29	2/Hr 20 19
168	2119 Promoción De Donación De Sangre 7pm December	16 7 49	1,600 94 5.80	1,852 138 8.47	588 0 0	2/Hr 27 36	2/Hr 27 26
169	21120 Centro Computo li 7pm December	13 5 38	1,384 82 6.38	2,776 207 16.16	315 0 0	2/Hr 21 31	2/Hr 21 40
170	21121 Sala De Control Elect. 7pm December	6 1 19	946 56 8.86	2,180 163 25.81	63 0 0	2/Hr 11 21	2/Hr 11 31
171	2122 Sala De Administr. 7pm December	9 2 28	1,139 67 7.15	1,440 107 11.42	126 0 0	2/Hr 16 25	2/Hr 16 21
173	21125 Jefatura 7pm December	12 3 36	1,306 77 6.43	1,312 98 8.16	189 0 0	2/Hr 20 28	2/Hr 20 19

ARQ. DAVID RECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION

MANUEL DONATO GARCIA JAVE
 ING. MECANICO ELECTRICISTA
 REC. CIP N° 69138

CONFORME



Nestor Enrique Ruiz P.
 Ingeniero Mecánico

CONSORCIO CONSULTOR SAUL GARRIDO

EDWARD GERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
174	2126 Central De Comunic 7pm December	9 2 27	1,110 66 7.20	1,107 83 9.08	126 0 0	2/Hr 15 25	2/Hr 15 16
175	2128 Oficina De Informatica 7pm December	24 4 72	2,126 125 5.21	2,861 213 8.86	252 0 0	2/Hr 40 48	2/Hr 25 41
178	2134 Sala De Usos Multiples 7pm December	103 82 310	5,316 314 3.04	10,327 770 7.45	3,875 0 0	2/Hr 172 119	2/Hr 172 147
179	2140 Sala De Espera 7pm December	377 135 1,130	17,572 1,037 2.75	24,467 1,825 4.84	11,340 0 0	2/Hr 628 393	2/Hr 628 349
180	2142 Triage 5pm January	13 3 39	1,315 78 5.93	2,554 190 14.54	252 0 0	2/Hr 22 29	2/Hr 22 36
181	2143 Consejeria Y Prevención Del Cancer 5pm January	14 3 42	1,382 82 5.78	2,431 181 12.86	252 0 0	2/Hr 24 31	2/Hr 24 35
182	2144 At Int Y Consejeria 5pm January	15 1 44	1,376 81 5.57	2,363 176 12.07	123 0 0	2/Hr 24 31	2/Hr 24 34
183	2145 Consultorio De Nutrición 5pm January	15 3 44	1,376 81 5.57	2,611 195 13.34	252 0 0	2/Hr 24 31	2/Hr 24 37
184	2146 Consultorio De Odontologia 5pm January	39 3 116	3,020 178 4.61	7,191 536 13.86	252 0 0	2/Hr 65 68	2/Hr 65 103
185	2148 Consultorio De Psiquiatria 5pm January	15 1 44	1,382 82 5.63	2,365 176 12.16	122 0 0	2/Hr 24 31	2/Hr 24 34
186	2149 Consultorio De Psicologia 5pm January	15 3 46	1,404 83 5.42	2,639 197 12.86	252 0 0	2/Hr 26 31	2/Hr 26 38

[Handwritten signature]

APRO. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISION

MANUEL DONATO GARCIA JAYE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 69138

CONFORME

CONSORCIO CONSULTOR SAUL GARRIDO

[Handwritten signature]
Nestor Enrique Ruiz P.
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Handwritten signature]
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
ONI N° 21546425

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
187	2151 Consultorio De Neumogolia 5pm January	15 3 44	1,376 81 5.57	2,611 195 13.34	252 0 0	2/Hr 24 31	2/Hr 24 37
188	2157 Consultorio De Cirugia 7pm December	17 3 51	1,678 99 5.79	1,562 117 6.81	252 0 0	2/Hr 29 38	2/Hr 29 22
189	2159 Topico De Procedimientos 7pm December	17 3 51	1,754 104 6.06	1,757 131 7.66	252 0 0	2/Hr 29 39	2/Hr 29 25
190	2160 Consultorio De Medicina Interna 7pm December	17 3 51	1,678 99 5.79	1,562 117 6.81	252 0 0	2/Hr 29 38	2/Hr 29 22
191	2161 Consultorio De Oftalmologia 7pm December	18 3 54	1,719 101 5.64	1,592 119 6.60	252 0 0	2/Hr 30 38	2/Hr 30 23
192	2162 Consultorio De Cardiologia 7pm December	17 3 51	1,670 99 5.77	1,558 116 6.80	252 0 0	2/Hr 29 37	2/Hr 29 22
193	2163 Tele Consultorio 7pm December	21 7 62	1,839 109 5.29	2,327 174 8.47	588 0 0	2/Hr 34 41	2/Hr 34 33
194	2164 Oficina De Estadistica 7pm December	27 3 82	2,163 128 4.66	1,906 142 5.19	252 0 0	2/Hr 46 48	2/Hr 46 27
195	301 Habitación 3pm April	15 2 44	1,296 77 5.24	1,802 134 9.21	168 0 0	2/Hr 24 29	2/Hr 24 26
196	303 Habitación 3pm April	14 2 43	1,286 76 5.31	1,781 133 9.29	168 0 0	2/Hr 24 29	2/Hr 24 25
197	306 Cocina Comedor 3pm April	39 6 116	2,607 154 3.98	4,401 328 8.48	504 0 0	2/Hr 65 58	2/Hr 65 63
198	307 Estación De Enfermeras 2pm May	53 3 158	2,836 167 3.18	7,361 549 10.44	189 0 0	2/Hr 88 63	2/Hr 88 105

Logo

ING. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

CONFORME

MANUEL DONATO GARCIA JAYE
ING. MECANICO ELECTRICISTA
REG. CIP N° 69138



Estor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP 25863

CONSORCIO CONSULTOR SAUL GARRIDO

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778

Handwritten notes in blue ink, possibly a signature or date.

Vertical handwritten notes in blue ink.

Vertical handwritten notes in blue ink.

Small handwritten notes in blue ink.

Large block of handwritten notes in blue ink at the bottom left.

Small handwritten notes in blue ink at the bottom right.



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
199	312 Topico De Procedimientos 3pm April	19 2 56	1,486 88 4.69	2,380 177 9.49	168 0 0	2/Hr 31 33	2/Hr 31 34
201	324 Sala De Espera Hosp Adulto 4pm January	40 12 121	2,096 124 3.08	8,280 618 15.36	1,008 0 0	2/Hr 67 47	2/Hr 67 118
202	325 Estar De Personal Hombres 4pm January	13 7 39	1,095 65 4.97	3,069 229 17.61	331 0 0	2/Hr 22 24	2/Hr 22 24
203	326 Estar De Personal Mujeres 4pm January	13 7 39	1,095 65 4.97	3,069 229 17.61	331 0 0	2/Hr 22 24	2/Hr 22 44
204	327 Oficina De Control Nutricional 4pm January	13 3 38	1,082 64 5.11	2,861 213 17.07	189 0 0	2/Hr 21 24	2/Hr 21 41
208	336 Sala De Reuniones 10am April	15 8 46	1,180 70 4.58	2,792 208 13.70	336 0 0	2/Hr 25 26	2/Hr 25 40
209	337 Jefatura 2pm May	13 3 38	1,091 64 5.03	2,636 197 15.36	189 0 0	2/Hr 21 24	2/Hr 21 38
210	339 Secretaria 3pm April	11 3 32	1,124 66 6.14	1,685 126 11.64	189 0 0	2/Hr 18 25	2/Hr 18 24
211	344 Topico De Procedimientos Pediatría 3pm April	17 2 50	1,379 81 4.90	2,193 164 9.85	94 0 0	2/Hr 28 31	2/Hr 28 31
216	352 Estación De Enfermería 3pm April	20 3 60	2,939 173 8.67	3,067 229 11.44	189 0 0	2/Hr 33 66	2/Hr 33 44
219	357 Lactario 3pm April	11 3 32	1,115 66 6.21	1,895 141 13.34	252 0 0	2/Hr 18 27	2/Hr 18 27
220	358 Sala De Juegos 2pm May	13 4 40	1,109 65 4.88	2,890 216 7.22	339 0 0	2/Hr 22 25	2/Hr 22 41

2/Hr
 ARQ. DAVID HECTOR TORRES PUELLO
 CAP. 8776
 JEFE DE SUPERVISIÓN

MANUEL DOMINGO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

CONFORME



EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61775

CONSORCIO CONSULTORES DEL GARRIDO

Nestor Enrique Ruiz



Air Handler #1 - Fc - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
230	384 Topico De Procedimientos 10am April	15	1,236	2,882	94	2/Hr	2/Hr
		2	73	215	0	25	25
		46	4.80	14.14	0	28	41
231	385 Sala De Espera Hosp Gineco 2pm January	35	2,551	5,196	1,008	2/Hr	2/Hr
		12	151	388	0	58	58
		104	4.34	11.17	0	57	74
Zone Peak Totals:		3,640	271,339	424,959	67,337		
Total Zones: 143		976	16,018	31,697	0	6,067	6,067
Unique Zones: 143		10,921	4.40	8.71	0	6,067	6,068

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 6776
 JEFE DE SUPERVISIÓN



[Signature]
 Néstor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 03136



CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD GERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #1 - Fc - Total Load Summary

Air Handler Description: Fc Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 3.96 kW
 Fan Input: 80% motor and fan efficiency with 0.1 kPa across the fan
 Sensible Heat Ratio: 0.86 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.46 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	271,339 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	22,024 Watts	6,067 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN
 293,364 Watts

Heating Supply Air: 271,339 / (1.000 X 1.21 X 14) =	16,018 L/s
Winter Vent Outside Air (37.9% of supply) =	6,067 L/s

Zone space sensible gain:	399,215 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	3,899 Watts
Reserve sensible gain:	25,733 Watts
Total sensible gain on supply side of coil:	



428,846 Watts

Cooling Supply Air: 428,846 / (1.000 X 1.23 X 11) =	31,696 L/s
Summer Vent Outside Air (19.1% of supply) =	6,067 L/s

Return duct sensible gain:	3,899 Watts
Return plenum sensible gain:	0 Watts
Outside air sensible gain:	52,240 Watts
Blow-thru fan sensible gain:	3,947 Watts
Total sensible gain on return side of coil:	
Total sensible gain on air handling system:	

60,085 Watts
 488,932 Watts

Zone space latent gain:	67,337 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	165,080 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	



232,416 Watts
 721,348 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	31,696 L/s	
Total Air Handler Vent. Air (19.14% of Supply):	6,067 L/s	
Total Conditioned Air Space:	3,640 Sq.m	
Supply Air Per Unit Area:	8.7067 L/s/Sq.m	
Area Per Cooling Capacity:	5.0467 Sq.m/kW	17.7484 Sq.m/Ton
Cooling Capacity Per Area:	0.1982 kW/Sq.m	0.0563 Tons/Sq.m
Total Heating Required With Outside Air:	293.36 kW	
Total Cooling With Outside Air:	721.35 kW	205.11 Tons



Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.R. N° 61778

42000

2000-0000-0000

2000-0000-0000

2000-0000-0000



Air Handler #2 - Uma-n1-obs - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
19	128 Uvi 7pm December	24 2 71	2,061 170 7.16	2,050 153 6.42	147 0 0	2/Hr 40 60	2/Hr 40 46
26	144 Sala De Observacion Mujeres 9am April	151 8 452	7,574 626 4.16	9,877 737 4.89	672 0 0	2/Hr 251 219	2/Hr 251 220
27	147 Sala De Observacion Hombres 7pm December	76 5 227	4,528 374 4.94	4,991 372 4.92	420 0 0	2/Hr 126 131	2/Hr 126 111
28	148 Sala De Observación Pediatria 9am April	43 3 128	2,710 224 5.26	4,961 370 8.69	252 0 0	2/Hr 71 78	2/Hr 71 111
Zone Peak Totals:		293	16,873	21,879	1,491		
Total Zones: 4		18	1,395	1,632	0	488	488
Unique Zones: 4		878	4.76	5.58	0	488	488

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 6776
 JEFE DE SUPERVISIÓN

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 ONI N° 2.1546425

[Signature]
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770



Air Handler #2 - Uma-n1-obs - Total Load Summary

Air Handler Description: Uma-n1-obs Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 0.94 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 1pm in April.
 Outdoor Conditions: 29° DB, 25° WB, 17.76 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in April at 9am is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 21,879.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	16,873 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	2,361 Watts	488 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		19,235 Watts

Heating Supply Air: 16,873 / (1.000 X 1.21 X 10) =	1,395 L/s
Winter Vent Outside Air (35.0% of supply) =	488 L/s

Zone space sensible gain:	19,774 Watts	
Infiltration sensible gain:	0 Watts	
Draw-thru fan sensible gain:	0 Watts	
Supply duct sensible gain:	201 Watts	
Reserve sensible gain:	0 Watts	
Total sensible gain on supply side of coil:		19,975 Watts

Cooling Supply Air: 22,080 / (1.000 X 1.23 X 11) =	1,632 L/s
Summer Vent Outside Air (29.9% of supply) =	488 L/s

Return duct sensible gain:	201 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	3,600 Watts	488 L/s
Blow-thru fan sensible gain:	0 Watts	
Total sensible gain on return side of coil:		3,801 Watts
Total sensible gain on air handling system:		23,776 Watts

Zone space latent gain:	1,491 Watts	
Infiltration latent gain:	0 Watts	
Outside air latent gain:	13,883 Watts	
Total latent gain on air handling system:		15,374 Watts
Total system sensible and latent gain:		39,150 Watts

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN



[Signature]
 MANUEL DOMATO GARCIA JUNE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138



Check Figures

Total Air Handler Supply Air (based on a 11° TD):	1,632 L/s	
Total Air Handler Vent. Air (29.89% of Supply):	488 L/s	
Total Conditioned Air Space:	293 Sq.m	
Supply Air Per Unit Area:	5.5756 L/s/Sq.m	
Area Per Cooling Capacity:	7.4765 Sq.m/kW	26.2936 Sq.m/Ton
Cooling Capacity Per Area:	0.1338 kW/Sq.m	0.0380 Tons/Sq.m
Total Heating Required With Outside Air:	19.23 kW	
Total Cooling With Outside Air:	39.15 kW	11.13 Tons

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

005016



Air Handler #3 - Uma-n1-laboratorio - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
21	131 Laboratorio Descentralizo 5pm January	13 3 38	1,265 80 6.43	2,861 213 17.07	142 0 0	None 0 80	None 0 213
58	1122 Laboratorio De Hematología 7pm December	17 4 51	1,670 106 6.25	2,586 193 11.35	588 0 0	None 0 106	None 0 193
59	1123 Lavado Y Desin 7pm December	10 1 30	1,278 81 8.04	1,116 101 10.00	47 0 0	None 0 81	None 0 101
60	1125 Esclusa 7pm December	4 1 12	687 44 10.92	565 42 10.54	84 0 0	None 0 44	None 0 42
61	1126 Laboratorio De Bioquimica 7pm December	17 4 51	1,655 105 6.15	2,580 192 11.25	588 0 0	None 0 105	None 0 192
62	1127 Laboratorio De Microbiología 7pm December	20 4 60	2,895 184 9.20	3,213 240 11.98	588 0 0	None 0 184	None 0 240
	Zone Peak Totals:	81	9,450	12,922	2,037		
	Total Zones: 6	17	601	982	0	0	0
	Unique Zones: 6	242	7.44	12.16	0	601	982

ARQ DAVID ESCOBAR TORRES PUNTE
CAP. 5776
JEFE DE SUPERVISIÓN

CONFORME



MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 63158

Nestor Enrique Ruiz P.
Ingeniero Mecánico
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778



Air Handler #3 - Uma-n1-laboratorio - Total Load Summary

Air Handler Description: Uma-n1-laboratorio Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.74 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.87 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 5pm in April.
 Outdoor Conditions: 29° DB, 25° WB, 17.72 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in January at 5pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 12,922.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	9,450 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	2,908 Watts	601 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN
 12,358 Watts

Heating Supply Air: $9,450 / (1.000 \times 1.21 \times 13) =$	601 L/s
Winter Vent Outside Air (100.0% of supply) =	601 L/s

Zone space sensible gain:	12,687 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	121 Watts
Reserve sensible gain:	244 Watts
Total sensible gain on supply side of coil:	



13,051 Watts

Cooling Supply Air: $13,287 / (1.000 \times 1.23 \times 11) =$	982 L/s
Summer Vent Outside Air (100.0% of supply) =	982 L/s

Return duct sensible gain:	0 Watts
Return plenum sensible gain:	0 Watts
Outside air sensible gain:	7,247 Watts
Blow-thru fan sensible gain:	734 Watts
Total sensible gain on return side of coil:	
Total sensible gain on air handling system:	

MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP. N° 60136

7,981 Watts
 21,033 Watts

Zone space latent gain:	2,037 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	27,948 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

29,985 Watts
 51,017 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	982 L/s
Total Air Handler Vent. Air (100.00% of Supply):	982 L/s

Total Conditioned Air Space:	81 Sq.m
Supply Air Per Unit Area:	12.1691 L/s/Sq.m
Area Per Cooling Capacity:	1.5818 Sq.m/kW
Cooling Capacity Per Area:	0.6322 kW/Sq.m



5.5630 Sq.m/Ton
 0.1798 Tons/Sq.m

Total Heating Required With Outside Air:	12.36 kW
Total Cooling With Outside Air:	51.02 kW

14.51 Tons

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29865

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #4 - Uma-n1-aisl.obse - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
29	150 Esclusa 7pm December	7 1 20	968 62 9.19	730 56 8.33	84 0 0	None 0 62	None 0 56
30	151 Sala De Observación Aislado 7pm December	18 2 54	1,745 111 6.20	1,666 179 10.00	158 0 0	None 0 111	None 0 179
Zone Peak Totals:		25	2,713	2,396	242		
Total Zones: 2		3	172	235	0	0	0
Unique Zones: 2		74	7.01	9.55	0	172	235


 ARQ. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME






 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 63138


 Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866


 CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425


 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #4 - Uma-n1-aisl.obse - Total Load Summary

Air Handler Description: Uma-n1-aisl.obse Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.18 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.93 --- This system occurs 1 time(s) in the building. ---
 Air System Peak Time: 5pm in April.
 Outdoor Conditions: 29° DB, 25° WB, 17.72 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in December at 7pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 2,396.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	2,713 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	835 Watts	172 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		
Heating Supply Air: $2,713 / (1.000 \times 1.21 \times 13) =$		172 L/s
Winter Vent Outside Air (100.0% of supply) =		172 L/s

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

3,547 Watts

Zone space sensible gain:	2,396 Watts	
Infiltration sensible gain:	0 Watts	
Draw-thru fan sensible gain:	0 Watts	
Supply duct sensible gain:	29 Watts	
Reserve sensible gain:	758 Watts	
Total sensible gain on supply side of coil:		

CONFORME
 3,183 Watts

Cooling Supply Air: $3,183 / (1.000 \times 1.23 \times 11) =$		235 L/s
Summer Vent Outside Air (100.0% of supply) =		235 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	1,736 Watts	235 L/s
Blow-thru fan sensible gain:	176 Watts	
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		1,912 Watts

5,095 Watts

Zone space latent gain:	242 Watts	
Infiltration latent gain:	0 Watts	
Outside air latent gain:	6,695 Watts	
Total latent gain on air handling system:		
Total system sensible and latent gain:		

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 63138

6,937 Watts
 12,032 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):		235 L/s
Total Air Handler Vent. Air (100.00% of Supply):		235 L/s
Total Conditioned Air Space:		25 Sq.m
Supply Air Per Unit Area:	9.5637	L/s/Sq.m
Area Per Cooling Capacity:	2.0446	Sq.m/kW
Cooling Capacity Per Area:	0.4891	kW/Sq.m
Total Heating Required With Outside Air:	3.55	kW
Total Cooling With Outside Air:	12.03	kW
		7.1906 Sq.m/Ton
		0.1391 Tons/Sq.m
		3.42 Tons



[Signature]
 Nestor Enrique Ruiz P.,
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

[Signature]
 CONSORCIO CONSULTOR SAUL GARRIDO
 REPRESENTANTE SAUL GARRIDO
 DNI N° 21546425



Air Handler #6 - Uma-n1-vih - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
75	1153 Consejeria Y Prevención De Its 2pm May	14 3 41	1,287 82 5.93	2,522 188 13.63	252 0 0	None 0 82	None 0 188
76	1154 Espera 5pm January	29 6 88	2,870 182 6.23	4,549 339 11.58	504 0 0	None 0 182	None 0 339
77	1156 Sala De Targa 7pm March	8 3 24	1,011 64 8.04	1,200 89 11.18	252 0 0	None 0 64	None 0 89
Zone Peak Totals:		51	5,168	8,271	1,008		
Total Zones: 3		12	329	617	0	0	0
Unique Zones: 3		153	6.43	12.07	0	329	617

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. C.I.P. N° 05108

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DMI N° 21546425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866



Air Handler #6 - Uma-n1-vih - Total Load Summary

Air Handler Description: Uma-n1-vih Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.46 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.89 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.46 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	5,168	Watts	
Infiltration sensible loss:	0	Watts	0 L/s
Outside Air sensible loss:	1,590	Watts	329 L/s
Supply Duct sensible loss:	0	Watts	
Return Duct sensible loss:	0	Watts	
Return Plenum sensible loss:	0	Watts	
Total System sensible loss:			

[Signature]
 ARQ DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION
 6,759 Watts

Heating Supply Air: 5,168 / (1.000 X 1.21 X 13) =	329	L/s
Winter Vent Outside Air (100.0% of supply) =	329	L/s

Zone space sensible gain:	7,501	Watts
Infiltration sensible gain:	0	Watts
Draw-thru fan sensible gain:	0	Watts
Supply duct sensible gain:	76	Watts
Reserve sensible gain:	761	Watts
Total sensible gain on supply side of coil:		

8,337 Watts

Cooling Supply Air: 8,337 / (1.000 X 1.23 X 11) =	616	L/s
Summer Vent Outside Air (100.0% of supply) =	616	L/s

CONFORME

Return duct sensible gain:	0	Watts
Return plenum sensible gain:	0	Watts
Outside air sensible gain:	5,306	Watts
Blow-thru fan sensible gain:	460	Watts
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

5,766 Watts
 14,104 Watts

Zone space latent gain:	1,008	Watts
Infiltration latent gain:	0	Watts
Outside air latent gain:	16,767	Watts
Total latent gain on air handling system:		
Total system sensible and latent gain:		

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

17,775 Watts
 31,878 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	616	L/s	
Total Air Handler Vent. Air (100.00% of Supply):	616	L/s	
Total Conditioned Air Space:	51	Sq.m	
Supply Air Per Unit Area:	12.0596	L/s/Sq.m	
Area Per Cooling Capacity:	1.6030	Sq.m/kW	5.6374 Sq.m/Ton
Cooling Capacity Per Area:	0.6238	kW/Sq.m	0.1774 Tons/Sq.m
Total Heating Required With Outside Air:	6.76	kW	
Total Cooling With Outside Air:	31.88	kW	9.06 Tons



[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29865

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA KUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Faint, illegible text at the top left of the page.

Faint, illegible text in the middle left section.

Faint, illegible text in the lower middle left section.

Faint, illegible text in the center of the page.

Faint, illegible text in the lower center section.

Faint, illegible text in the bottom left section.

Faint, illegible text in the bottom right section.



Air Handler #7 - Uma-n1-tbc - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
96	1190 Toma De Medic 3pm January	8	857	1,962	168	None	None
		2	54	146	0	0	0
		24	6.73	18.07	0	54	146
97	1193 Prevención Y Control Tbc 2pm May	14	1,142	2,615	252	None	None
		3	73	195	0	0	0
		41	5.38	14.45	0	73	195
Zone Peak Totals:		22	1,999	4,577	420		
Total Zones: 2		5	127	341	0	0	0
Unique Zones: 2		65	5.88	15.81	0	127	341

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29866

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 60136

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21946429

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #7 - Uma-n1-tbc - Total Load Summary

Air Handler Description: Uma-n1-tbc Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.25 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.92 --- This system occurs 1 time(s) in the building, ---
 Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in May at 3pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 4,244.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss: 1,999 Watts
 Infiltration sensible loss: 0 Watts 0 L/s
 Outside Air sensible loss: 615 Watts 127 L/s
 Supply Duct sensible loss: 0 Watts
 Return Duct sensible loss: 0 Watts
 Return Plenum sensible loss: 0 Watts
 Total System sensible loss: 2,614 Watts

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 6776
 JEFE DE SUPERVISIÓN

Heating Supply Air: 1,999 / (1.000 X 1.21 X 13) = 127 L/s
 Winter Vent Outside Air (100.0% of supply) = 127 L/s

Zone space sensible gain: 4,222 Watts
 Infiltration sensible gain: 0 Watts
 Draw-thru fan sensible gain: 0 Watts
 Supply duct sensible gain: 42 Watts
 Reserve sensible gain: 321 Watts
 Total sensible gain on supply side of coil: 4,585 Watts



Cooling Supply Air: 4,607 / (1.000 X 1.23 X 11) = 341 L/s
 Summer Vent Outside Air (100.0% of supply) = 341 L/s

Return duct sensible gain: 0 Watts
 Return plenum sensible gain: 0 Watts
 Outside air sensible gain: 2,932 Watts 341 L/s
 Blow-thru fan sensible gain: 254 Watts
 Total sensible gain on return side of coil: 3,186 Watts
 Total sensible gain on air handling system: 7,772 Watts

Zone space latent gain: 420 Watts
 Infiltration latent gain: 0 Watts
 Outside air latent gain: 9,265 Watts
 Total latent gain on air handling system: 9,685 Watts
 Total system sensible and latent gain: 17,457 Watts

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Check Figures

Total Air Handler Supply Air (based on a 11° TD): 341 L/s
 Total Air Handler Vent. Air (100.00% of Supply): 341 L/s
 Total Conditioned Air Space: 22 Sq.m
 Supply Air Per Unit Area: 15.7652 L/s/Sq.m
 Area Per Cooling Capacity: 1.2373 Sq.m/kW 4.3515 Sq.m/Ton
 Cooling Capacity Per Area: 0.8082 kW/Sq.m 0.2298 Tons/Sq.m
 Total Heating Required With Outside Air: 2.61 kW
 Total Cooling With Outside Air: 17.46 kW 4.96 Tons



CONSORCIO CONSULTOR SAUL GARRIDO

[Signature]
 Nestor Enrique Ruiz R.,
 Ingeniero Mecánico
 Reg. CIP 29866

[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

000000

000000

000000

000000

000000

000000




Air Handler #8 - Uma-n2-sm - Summary Loads


Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
107	201 Sala Multifunciones 4pm April	38 8 113	1,064 68 1.79	5,216 473 12.50	1,176 0 0	None 0 68	None 0 473
Zone Peak Totals:		38	1,064	5,216	1,176		
Total Zones: 1		8	68	473	0	0	0
Unique Zones: 1		113	1.79	12.50	0	68	473


 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME





 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 09193


 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBALLO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425


 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #8 - Uma-n2-sm - Total Load Summary

Air Handler Description: Uma-n2-sm Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.35 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.84 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.46 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	1,064 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	327 Watts	68 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		1,392 Watts

ARQ. DAVID HECTOR TORRES PUNTES
 CAP. 5776
 JEFE DE SUPERVISIÓN

Heating Supply Air: 1,064 / (1.000 X 1.21 X 13) = 68 L/s
 Winter Vent Outside Air (100.0% of supply) = 68 L/s

Zone space sensible gain:	5,216 Watts	
Infiltration sensible gain:	0 Watts	
Draw-thru fan sensible gain:	0 Watts	
Supply duct sensible gain:	58 Watts	
Reserve sensible gain:	1,128 Watts	
Total sensible gain on supply side of coil:		6,401 Watts

CONFORME

Cooling Supply Air: 6,401 / (1.000 X 1.23 X 11) = 473 L/s
 Summer Vent Outside Air (100.0% of supply) = 473 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	4,074 Watts	473 L/s
Blow-thru fan sensible gain:	354 Watts	
Total sensible gain on return side of coil:		4,427 Watts
Total sensible gain on air handling system:		10,829 Watts

MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138
 14,049 Watts
 24,878 Watts

Zone space latent gain:	1,176 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	12,873 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	473 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	473 L/s	
Total Conditioned Air Space:	38 Sq.m	
Supply Air Per Unit Area:	12.5170 L/s/Sq.m	
Area Per Cooling Capacity:	1.5194 Sq.m/kW	5.3436 Sq.m/Ton
Cooling Capacity Per Area:	0.6581 kW/Sq.m	0.1871 Tons/Sq.m
Total Heating Required With Outside Air:	1.39 kW	
Total Cooling With Outside Air:	24.88 kW	7.07 Tons



Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29886

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 6177R

005006



Air Handler #9 - Uma-n2-dil - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
108	203 Atenci3n	15	1,174	2,151	72	2/Hr	2/Hr
	Inmediata Al Reci3n	2	97	160	0	26	26
	Nacido 4pm May	46	6.34	10.49	0	29	26
111	208 Sala De	29	2,401	2,398	189	2/Hr	2/Hr
	Puerperio Inmediato	4	198	292	0	49	49
	7pm December	88	6.80	10.00	0	59	47
114	213 Sala De	55	3,044	5,278	441	2/Hr	2/Hr
	Dilataci3n	3	252	548	0	91	91
	3pm April	164	4.59	10.00	0	75	87
115	223 Sala De	20	1,449	3,338	252	2/Hr	2/Hr
	Monitoreo Fetal	3	120	249	0	34	34
	10am April	61	5.90	12.27	0	36	40
Zone Peak Totals:		120	8,067	13,165	954		
Total Zones: 4		12	667	1,249	0	199	199
Unique Zones: 4		359	5.57	10.45	0	199	199

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISI3N

CONFORME

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29866



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #9 - Uma-n2-dil - Total Load Summary

Air Handler Description: Uma-n2-dil Constant Volume - Sum of Peaks
Sensible Heat Ratio: 0.95 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	8,067 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	965 Watts	199 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		9,032 Watts

[Signature]
ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISIÓN

Heating Supply Air: 8,067 / (1.000 X 1.21 X 10) = 667 L/s
Winter Vent Outside Air (29.9% of supply) = 199 L/s

Zone space sensible gain:	12,931 Watts	
Infiltration sensible gain:	0 Watts	
Draw-thru fan sensible gain:	0 Watts	
Supply duct sensible gain:	154 Watts	
Reserve sensible gain:	3,829 Watts	
Total sensible gain on supply side of coil:		16,913 Watts

Cooling Supply Air: 16,913 / (1.000 X 1.23 X 11) = 1,250 L/s
Summer Vent Outside Air (15.9% of supply) = 199 L/s

Return duct sensible gain:	154 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	1,716 Watts	199 L/s
Blow-thru fan sensible gain:	0 Watts	
Total sensible gain on return side of coil:		1,870 Watts
Total sensible gain on air handling system:		18,783 Watts

CONFORME

Zone space latent gain:	954 Watts	
Infiltration latent gain:	0 Watts	
Outside air latent gain:	5,423 Watts	
Total latent gain on air handling system:		6,378 Watts
Total system sensible and latent gain:		25,161 Watts

[Signature]
MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REC. CIP N° 69138

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	1,250 L/s	
Total Air Handler Vent. Air (15.95% of Supply):	199 L/s	
Total Conditioned Air Space:	120 Sq.m	
Supply Air Per Unit Area:	10.4522 L/s/Sq.m	
Area Per Cooling Capacity:	4.7534 Sq.m/kW	16.7171 Sq.m/Ton
Cooling Capacity Per Area:	0.2104 kW/Sq.m	0.0598 Tons/Sq.m
Total Heating Required With Outside Air:	9.03 kW	
Total Cooling With Outside Air:	25.16 kW	7.15 Tons



[Signature]
Nestor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMUN
DNI N° 21546425

[Signature]
EDWARD CEBRON TORRES
JEFE DE PROYECTO
C.I.P. N° 61778



Air Handler #10 - Dx - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
20	130 Almacen Medicamento 5pm January	12 1 37	1,220 72 5.86	2,577 265 21.56	47 0 0	2/Hr 21 24	2/Hr 21 21
22	132 Cuarto Técnico 7pm January	9 1 28	1,143 67 7.18	2,470 254 27.04	79 0 0	2/Hr 21 22	2/Hr 16 20
45	197 Sala De Telecom 7pm January	13 1 39	1,192 70 5.46	2,656 273 21.19	84 0 0	2/Hr 22 23	2/Hr 22 22
65	1134 Cuarto Técnico 7pm December	7 1 22	141 8 1.13	1,805 186 25.11	84 0 0	2/Hr 12 3	2/Hr 12 15
68	1138 Sala De Telecom 7pm December	17 1 51	1,583 93 5.53	2,606 268 15.87	84 0 0	2/Hr 28 31	2/Hr 28 21
69	1139 Cuarto Técnico 7pm December	10 1 31	1,459 86 8.28	2,477 255 24.52	84 0 0	2/Hr 17 28	2/Hr 17 20
71	1142 Cto Técnico 7pm December	11 1 32	1,297 77 7.16	2,402 247 23.10	84 0 0	2/Hr 18 25	2/Hr 18 20
78	1157 Almacen De Medic. 7pm December	6 1 18	863 51 8.49	1,197 123 20.52	84 0 0	2/Hr 10 17	2/Hr 10 10
94	1186 Sala De Telecom 7pm December	12 1 36	794 47 3.87	2,190 225 18.62	102 0 0	2/Hr 20 15	2/Hr 20 18
95	1189 Almac De Medicam 3pm January	6 1 18	672 40 6.50	949 98 16.01	47 0 0	2/Hr 10 13	2/Hr 10 8
98	1213 Jefatura Soporte Técnico 2pm May	12 3 37	1,070 63 5.14	2,768 285 23.16	252 0 0	2/Hr 21 21	2/Hr 21 23
99	1214 Recepción 4pm January	16 2 49	1,356 80 4.94	3,423 352 21.75	702 0 0	2/Hr 27 26	2/Hr 27 28

CONFORME

MANUEL DONATO GARCIA JAYE
 ING. MECANICO-ELECTRICISTA
 REC. CIP N° 85138



Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUNOZ
 REPRESENTANTE COMUN
 DMI N° 21546425



Air Handler #10 - Dx - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
100	1231 Jefatura Y Secretaria 5pm January	15 6 46	941 56 3.66	4,015 413 27.19	504 0 0	2/Hr 25 18	2/Hr 25 33
101	1239 Recepci3n Y Despacho 4pm January	26 2 79	1,163 69 2.60	3,703 381 14.43	126 0 0	2/Hr 44 30	2/Hr 44 30
102	1240 Jefatura 2pm May	10 1 31	913 54 5.18	2,207 227 21.84	63 0 0	2/Hr 17 18	2/Hr 17 18
103	1244 Almacen De Medicamentos 3pm January	26 1 77	1,544 91 3.55	3,994 411 15.99	84 0 0	2/Hr 43 30	2/Hr 43 33
104	1250 Unidad De Salud Ambiental 4pm January	21 6 62	1,073 63 3.08	3,289 338 16.43	504 0 0	2/Hr 34 21	2/Hr 34 27
105	1251 Sala De Telecom 3pm January	12 1 37	1,172 69 5.67	2,961 305 24.98	102 0 0	2/Hr 20 23	2/Hr 20 24
106	1256 Jefatura 3pm May	12 3 37	965 57 4.67	1,829 188 15.43	189 0 0	2/Hr 20 19	2/Hr 20 15
119	229 Cuarto T3cnico 3pm January	10 1 30	334 20 1.95	2,413 248 24.59	85 0 0	2/Hr 17 6	2/Hr 17 20
127	238 Cuarto T3cnico 3pm January	10 1 31	1,135 67 6.57	2,809 289 28.34	86 0 0	2/Hr 17 22	2/Hr 17 23
155	192 Sala De Telecom 7pm December	12 1 36	1,406 83 6.91	2,485 256 21.31	101 0 0	2/Hr 20 27	2/Hr 20 20
176	2130 Sala De Telecom Iii 7pm December	17 1 51	1,605 95 5.61	2,617 269 15.93	84 0 0	2/Hr 28 31	2/Hr 28 21
177	2131 Cuarto Tecnico 7pm December	10 1 31	1,211 71 6.94	2,358 243 23.56	82 0 0	2/Hr 17 19	2/Hr 17 19

Handwritten signature

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5/76
 JEFE DE SUPERVISI3N

CONFORME

MANUEL DONATO GARCIA LIME
 ING. MECANICO-ELECTRICISTA
 REC. CIP N° 63138

GOBIERNO REGIONAL
 GOBIERNO DE PERU
 REGIONAL
 GOBIERNO REGIONAL

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

Nestor Enrique Ruiz P.,
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 REG. CIP N° 46625



Air Handler #10 - Dx - Summary Loads (cont'd)

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
214	348 Cuarto Tecnico 3pm January	10	1,075	2,794	87	2/Hr	2/Hr
		1	63	288	0	17	17
		31	6.10	27.64	0	21	23
215	347 Sala De Telecom 3pm January	10	1,365	2,935	87	2/Hr	2/Hr
		1	81	302	0	17	17
		31	7.75	29.04	0	26	24
234	392 Sala De Telecomun Iii 3pm January	12	1,342	3,031	101	2/Hr	2/Hr
		1	79	312	0	20	20
		36	6.60	25.99	0	26	25
Zone Peak Totals:		348	30,035	70,959	3,423		
Total Zones: 27		44	1,773	7,303	0	580	580
Unique Zones: 27		1,043	5.10	21.00	0	580	580

[Handwritten Signature]

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN



[Handwritten Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866



[Handwritten Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

CONSORCIO CONSULTOR SAUL GARRIDO
[Handwritten Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Handwritten Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #10 - Dx - Total Load Summary

Air Handler Description: Dx Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.91 kW
 Fan Input: 80% motor and fan efficiency with 0.1 kPa across the fan
 Sensible Heat Ratio: 0.95 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in January.
 Outdoor Conditions: 30° DB, 24° WB, 16.50 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	30,035 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	2,104 Watts	580 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

[Signature]
 ARQ. DAVID HECTOR TORRES PUNTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

Heating Supply Air: 30,035 / (1.000 X 1.21 X 14) =	1,773 L/s
Winter Vent Outside Air (32.7% of supply) =	580 L/s

Zone space sensible gain:	69,469 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	898 Watts
Reserve sensible gain:	1,485 Watts
Total sensible gain on supply side of coil:	

CONFORME

Cooling Supply Air: 71,852 / (1.000 X 1.23 X 8) =	7,302 L/s
Summer Vent Outside Air (7.9% of supply) =	580 L/s

Return duct sensible gain:	898 Watts
Return plenum sensible gain:	0 Watts
Outside air sensible gain:	7,128 Watts
Blow-thru fan sensible gain:	909 Watts
Total sensible gain on return side of coil:	
Total sensible gain on air handling system:	

Zone space latent gain:	3,423 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	15,548 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Check Figures

Total Air Handler Supply Air (based on a 8° TD):	7,302 L/s
Total Air Handler Vent. Air (7.94% of Supply):	580 L/s

Total Conditioned Air Space:	348 Sq.m	
Supply Air Per Unit Area:	21.0010 L/s/Sq.m	
Area Per Cooling Capacity:	3.4854 Sq.m/kW	12.2577 Sq.m/Ton
Cooling Capacity Per Area:	0.2869 kW/Sq.m	0.0816 Tons/Sq.m



Total Heating Required With Outside Air:	32.14 kW	
Total Cooling With Outside Air:	99.76 kW	28.37 Tons

[Signature]
 Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 6177



Air Handler #11 - Uma-n2-sp - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
109	204 Sala De Partos 3pm April	34 3 101	1,738 111 3.28	3,761 421 12.50	441 0 0	None 0 111	None 0 421
Zone Peak Totals:		34	1,738	3,761	441		
Total Zones: 1		3	111	421	0	0	0
Unique Zones: 1		101	3.28	12.50	0	111	421

ARQ. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISION
CONFIRMADO

Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DMI N° 21546425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

1948
MAY 15 1948
11300

11300

11300



Air Handler #11 - Uma-n2-sp - Total Load Summary

Air Handler Description: Uma-n2-sp Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.32 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.93 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	1,738 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	535 Watts	111 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 6776
 JEFE DE SUPERVISION
 2,279 Watts

Heating Supply Air: 1,738 / (1.000 X 1.21 X 13) =	111 L/s
Winter Vent Outside Air (100.0% of supply) =	111 L/s

Zone space sensible gain:	3,761 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	52 Watts
Reserve sensible gain:	1,891 Watts
Total sensible gain on supply side of coil:	

CONFORME
 5,704 Watts

Cooling Supply Air: 5,704 / (1.000 X 1.23 X 11) =	422 L/s
Summer Vent Outside Air (100.0% of supply) =	422 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	3,630 Watts	422 L/s
Blow-thru fan sensible gain:	315 Watts	
Total sensible gain on return side of coil:		3,945 Watts
Total sensible gain on air handling system:		9,649 Watts

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138
 11,912 Watts
 21,561 Watts

Zone space latent gain:	441 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	11,471 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	422 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	422 L/s	
Total Conditioned Air Space:	34 Sq.m	
Supply Air Per Unit Area:	12.5105 L/s/Sq.m	
Area Per Cooling Capacity:	1.5630 Sq.m/kW	5.4969 Sq.m/Ton
Cooling Capacity Per Area:	0.6398 kW/Sq.m	0.1819 Tons/Sq.m
Total Heating Required With Outside Air:	2.27 kW	
Total Cooling With Outside Air:	21.56 kW	6.13 Tons



[Signature]
 Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 6...

302106

Administrative

10/1/80

10/1/80
10/1/80
10/1/80

10/1/80

Administrative

10/1/80

10/1/80



Air Handler #12 - Uma-n2-so-gin - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
116	226 Sala De Operaciones De Ginecologia Y 3pm April	40	2,229	5,979	1,176	None	None
		8	142	499	0	0	0
		120	3.55	12.50	0	142	499
117	227 Filtro 3pm April	9	330	818	84	None	None
		1	21	61	0	0	0
		26	2.39	6.93	0	21	61
Zone Peak Totals:		49	2,560	6,797	1,260		
Total Zones: 2		9	163	560	0	0	0
Unique Zones: 2		146	3.34	11.49	0	163	560

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

[Signature]
 Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #12 - Uma-n2-so-gin - Total Load Summary

Air Handler Description: Uma-n2-so-gin Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.42 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.86 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	2,560 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	788 Watts	163 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN
 3,347 Watts

Heating Supply Air: 2,560 / (1.000 X 1.21 X 13) =	163 L/s
Winter Vent Outside Air (100.0% of supply) =	163 L/s

Zone space sensible gain:	6,797 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	69 Watts
Reserve sensible gain:	712 Watts
Total sensible gain on supply side of coil:	

7,579 Watts

Cooling Supply Air: 7,579 / (1.000 X 1.23 X 11) =	560 L/s
Summer Vent Outside Air (100.0% of supply) =	560 L/s

Return duct sensible gain:	0 Watts
Return plenum sensible gain:	0 Watts
Outside air sensible gain:	4,823 Watts
Blow-thru fan sensible gain:	419 Watts
Total sensible gain on return side of coil:	
Total sensible gain on air handling system:	

5,242 Watts
 12,820 Watts

Zone space latent gain:	1,260 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	15,241 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

16,501 Watts
 29,321 Watts



Check Figures

Total Air Handler Supply Air (based on a 11° TD):	560 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	560 L/s	
Total Conditioned Air Space:	49 Sq.m	
Supply Air Per Unit Area:	11.5024 L/s/Sq.m	
Area Per Cooling Capacity:	1.6609 Sq.m/kW	5.8412 Sq.m/Ton
Cooling Capacity Per Area:	0.6021 kW/Sq.m	0.1712 Tons/Sq.m
Total Heating Required With Outside Air:	3.35 kW	
Total Cooling With Outside Air:	29.32 kW	8.34 Tons



[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #13 - Uma-n2-legrado - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
118	228 Sala De Legrado 3pm April	24 8 72	1,750 111 4.62	4,905 366 15.18	1,176 0 0	None 0 111	None 0 366
Zone Peak Totals:		24	1,750	4,905	1,176		
Total Zones: 1		8	111	366	0	0	0
Unique Zones: 1		72	4.62	15.18	0	111	366

[Signature]
 ARQ. EDUARDO CERON TORRES PUNTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DM N° 21546425

[Signature]
 EDUARDO CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

6/2/20

1/1/20

1/1/20

1/1/20

1/1/20

1/1/20

1/1/20

1/1/20

1/1/20

1/1/20



Air Handler #13 - Uma-n2-legrado - Total Load Summary

Air Handler Description: Uma-n2-legrado Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.27 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.81 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	1,750 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	538 Watts	111 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

Heating Supply Air: $1,750 / (1.000 \times 1.21 \times 13) =$	111 L/s
Winter Vent Outside Air (100.0% of supply) =	111 L/s

Zone space sensible gain:	4,905 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	45 Watts
Reserve sensible gain:	0 Watts
Total sensible gain on supply side of coil:	

Cooling Supply Air: $4,950 / (1.000 \times 1.23 \times 11) =$	366 L/s
Summer Vent Outside Air (100.0% of supply) =	366 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	3,151 Watts	366 L/s
Blow-thru fan sensible gain:	273 Watts	
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

Zone space latent gain:	1,176 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	9,956 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	366 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	366 L/s	
Total Conditioned Air Space:	24 Sq.m	
Supply Air Per Unit Area:	15.1836 L/s/Sq.m	
Area Per Cooling Capacity:	1.2355 Sq.m/kW	4.3450 Sq.m/Ton
Cooling Capacity Per Area:	0.8094 kW/Sq.m	0.2301 Tons/Sq.m
Total Heating Required With Outside Air:	2.29 kW	
Total Cooling With Outside Air:	19.51 kW	5.55 Tons

Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
Maria Luisa Carabajo Muñoz
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 D.O.I. N° 21946429

Edward Cerón Torres
 JEFE DE PROYECTO
 C.I.P. N° 617

David Hecctor Torres Puente
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN
 2,288 Watts



Mandel Donato Garcia Jave
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138





Air Handler #14 - Uma-n2-induc - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
121	233 Sala De Inducción Anestesia 3pm April	27	1,846	3,112	94	2/Hr	2/Hr
		2	153	232	0	45	45
		81	5.65	8.60	0	51	53
123	235 Almace De Medic 3pm April	6	837	1,131	84	2/Hr	2/Hr
		1	69	84	0	10	10
		18	11.34	13.83	0	23	19
124	236 Corredor Rigido 3pm April	105	5,956	9,345	630	2/Hr	2/Hr
		8	492	697	0	176	176
		316	4.67	6.61	0	163	159
125	236.1 Almacen De Insumos 3pm April	9	308	802	84	2/Hr	2/Hr
		1	25	60	0	15	15
		26	2.93	6.88	0	8	14
Zone Peak Totals:		147	8,948	14,389	893		
Total Zones: 4		12	739	1,073	0	245	245
Unique Zones: 4		442	5.02	7.29	0	245	245

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECÁNICO-ELECTRICISTA
 REG. CIP N° 59138

[Signature]
 Nestor Enrique Ruiz R.,
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DMI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61111

003197

1954

1954
1954
1954

1954

1954

1954

1954



Air Handler #14 - Uma-n2-induc - Total Load Summary

Air Handler Description: Uma-n2-induc Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 0.94 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	8,948 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	1,187 Watts	245 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		10,135 Watts

Heating Supply Air: $8,948 / (1.000 \times 1.21 \times 10) =$	739 L/s
Winter Vent Outside Air (33.2% of supply) =	245 L/s

Zone space sensible gain:	14,389 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	132 Watts
Reserve sensible gain:	0 Watts
Total sensible gain on supply side of coil:	

DR. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION

Cooling Supply Air: $14,521 / (1.000 \times 1.23 \times 11) =$	1,073 L/s
Summer Vent Outside Air (22.9% of supply) =	245 L/s

Return duct sensible gain:	132 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	2,112 Watts	245 L/s
Blow-thru fan sensible gain:	0 Watts	
Total sensible gain on return side of coil:		2,244 Watts
Total sensible gain on air handling system:		16,765 Watts

Zone space latent gain:	893 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	6,675 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 031.8

7,567 Watts
 24,333 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	1,073 L/s
Total Air Handler Vent. Air (22.86% of Supply):	245 L/s

Total Conditioned Air Space:	147 Sq.m	
Supply Air Per Unit Area:	7.2913 L/s/Sq.m	
Area Per Cooling Capacity:	6.0494 Sq.m/kW	21.2750 Sq.m/Ton
Cooling Capacity Per Area:	0.1653 kW/Sq.m	0.0470 Tons/Sq.m

Total Heating Required With Outside Air:	10.14 kW	
Total Cooling With Outside Air:	24.33 kW	6.92 Tons



CONFORME

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBALLO MUÑOZ
 REPRESENTANTE COMÚN
 OMI N° 21546425

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #15 - Uma-n2-so-cirugia - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
120	231 Filtro 3pm April	5 0 14	692 44 9.78	719 54 11.91	38 0 0	None 0 44	None 0 54
122	234 Sala De Operaciones General 7pm December	40 8 120	1,833 117 2.91	4,084 501 12.50	1,176 0 0	None 0 117	None 0 501
Zone Peak Totals:		45	2,525	4,803	1,214		
Total Zones: 2		8	161	555	0	0	0
Unique Zones: 2		134	3.60	12.44	0	161	555

ING. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REC. CIP N° 69138

CONFORME

Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAÑO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #15 - Uma-n2-so-cirurgía - Total Load Summary

Air Handler Description: Uma-n2-so-cirurgía Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.42 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.86 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	2,525 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	777 Watts	161 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

[Handwritten Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 3,002 AVERSIÓN

Heating Supply Air: 2,525 / (1.000 X 1.21 X 13) = 161 L/s
 Winter Vent Outside Air (100.0% of supply) = 161 L/s

Zone space sensible gain:	4,803 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	68 Watts
Reserve sensible gain:	2,642 Watts
Total sensible gain on supply side of coil:	

7,514 Watts

Cooling Supply Air: 7,514 / (1.000 X 1.23 X 11) = 555 L/s
 Summer Vent Outside Air (100.0% of supply) = 555 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	4,782 Watts	555 L/s
Blow-thru fan sensible gain:	415 Watts	
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

5,197 Watts
 12,710 Watts

Zone space latent gain:	1,214 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	15,110 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

[Handwritten Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

16,324 Watts
 29,034 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	555 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	555 L/s	
Total Conditioned Air Space:	45 Sq.m	
Supply Air Per Unit Area:	12.4520 L/s/Sq.m	
Area Per Cooling Capacity:	1.5361 Sq.m/kW	5.4023 Sq.m/Ton
Cooling Capacity Per Area:	0.6510 kW/Sq.m	0.1851 Tons/Sq.m
Total Heating Required With Outside Air:	3.30 kW	
Total Cooling With Outside Air:	29.03 kW	8.26 Tons



[Handwritten Signature]
 Nestor Enrique Ruiz F.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Handwritten Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI Nº 21546425

[Handwritten Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #16 - Uma-n2-so-est - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
133	253 Preparación Y Empaque 3pm April	29	1,938	4,376	189	None	None
		4	123	326	0	0	0
		88	4.19	11.10	0	123	326
135	255 Descontaminación Y Desinfección 3pm April	30	2,231	4,534	189	None	None
		4	142	338	0	0	0
		89	4.78	11.39	0	142	338
136	256 Esterilización 3pm April	31	1,990	4,475	189	None	None
		4	126	334	0	0	0
		92	4.11	10.84	0	126	334
137	257 Almacen De Material Esteril 3pm April	40	2,751	5,120	47	None	None
		1	175	382	0	0	0
		120	4.36	9.52	0	175	382
138	258 Esclusa 3pm April	6	828	895	47	None	None
		1	53	67	0	0	0
		18	8.92	11.31	0	53	67
139	260 Entrega De Material Esteril 3pm April	7	893	1,200	47	None	None
		1	57	90	0	0	0
		21	7.99	12.61	0	57	90
Zone Peak Totals:		143	10,630	20,601	709		
Total Zones: 6		15	676	1,537	0		
Unique Zones: 6		429	4.73	10.75	0		

[Signature]
 ARO DAVID HECTOR TORRES PUENTE
 676 CAP. 517537
 JEFE DE SUPERVISIÓN



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. C.I.P. N° 69138

CONFORME

[Signature]
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #16 - Uma-n2-so-est - Total Load Summary

Air Handler Description: Uma-n2-so-est Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 1.15 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.97 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	10,630	Watts	
Infiltration sensible loss:	0	Watts	0 L/s
Outside Air sensible loss:	3,271	Watts	676 L/s
Supply Duct sensible loss:	0	Watts	
Return Duct sensible loss:	0	Watts	
Return Plenum sensible loss:	0	Watts	
Total System sensible loss:			

Heating Supply Air: $10,630 / (1,000 \times 1.21 \times 13) =$	676	L/s
Winter Vent Outside Air (100.0% of supply) =	676	L/s

Zone space sensible gain:	20,601	Watts
Infiltration sensible gain:	0	Watts
Draw-thru fan sensible gain:	0	Watts
Supply duct sensible gain:	189	Watts
Reserve sensible gain:	0	Watts
Total sensible gain on supply side of coil:		

Cooling Supply Air: $20,790 / (1,000 \times 1.23 \times 11) =$	1,537	L/s
Summer Vent Outside Air (100.0% of supply) =	1,537	L/s

Return duct sensible gain:	0	Watts
Return plenum sensible gain:	0	Watts
Outside air sensible gain:	13,230	Watts
Blow-thru fan sensible gain:	1,148	Watts
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

Zone space latent gain:	709	Watts
Infiltration latent gain:	0	Watts
Outside air latent gain:	41,808	Watts
Total latent gain on air handling system:		
Total system sensible and latent gain:		

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	1,537	L/s	
Total Air Handler Vent. Air (100.00% of Supply):	1,537	L/s	
Total Conditioned Air Space:	143	Sq.m	
Supply Air Per Unit Area:	10.7455	L/s/Sq.m	
Area Per Cooling Capacity:	1.8408	Sq.m/kW	6.4737 Sq.m/Ton
Cooling Capacity Per Area:	0.5432	kW/Sq.m	0.1545 Tons/Sq.m
Total Heating Required With Outside Air:	13.90	kW	
Total Cooling With Outside Air:	77.68	kW	22.09 Tons

[Handwritten Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 6776
 13,907 DE SUPERVISIÓN

CONFORME

[Handwritten Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138



[Handwritten Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
[Handwritten Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Handwritten Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

004988



Air Handler #17 - Uma-n2-lab. Inmunohemt. - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
159	1104 Recepc Uuss Y Hemoc 7pm December	11 1 32	1,236 79 7.28	1,423 106 9.83	63 0 0	None 0 79	None 0 106
163	2110 Laboratorio Inmunohemta 7pm December	23 4 68	1,922 122 5.38	2,768 227 10.00	588 0 0	None 0 122	None 0 227
164	2111 Esterilización Y Productos Biologic 7pm December	12 1 37	1,394 89 7.27	1,305 122 10.00	63 0 0	None 0 89	None 0 122
165	2112 Control De Calidad 7pm December	12 1 37	1,394 89 7.27	1,200 122 10.00	63 0 0	None 0 89	None 0 122
166	2114 Almacen Unidades De Sangre 7pm December	24 1 72	1,994 127 5.28	2,345 175 7.29	47 0 0	None 0 127	None 0 175
Zone Peak Totals:		82	7,941	9,041	824		
Total Zones: 5		8	505	752	0	0	0
Unique Zones: 5		246	6.16	9.18	0	505	752

[Signature]
 ARQ DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #17 - Uma-n2-lab. Inmunohemt. - Total Load Summary

Air Handler Description: Uma-n2-lab. Inmunohemt. Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.56 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.93 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 5pm in April.
 Outdoor Conditions: 29° DB, 25° WB, 17.72 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in December at 7pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 9,041.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	7,941 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	2,443 Watts	505 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

ARQ. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN

Heating Supply Air: $7,941 / (1.000 \times 1.21 \times 13) =$	505 L/s
Winter Vent Outside Air (100.0% of supply) =	505 L/s

Zone space sensible gain:	9,041 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	93 Watts
Reserve sensible gain:	1,049 Watts
Total sensible gain on supply side of coil:	

10,183 Watts

Cooling Supply Air: $10,183 / (1.000 \times 1.23 \times 11) =$	753 L/s
Summer Vent Outside Air (100.0% of supply) =	753 L/s

Return duct sensible gain:	0 Watts
Return plenum sensible gain:	0 Watts
Outside air sensible gain:	5,554 Watts
Blow-thru fan sensible gain:	562 Watts
Total sensible gain on return side of coil:	
Total sensible gain on air handling system:	

6,117 Watts
 16,299 Watts

Zone space latent gain:	824 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	21,419 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

22,243 Watts
 38,542 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	753 L/s
Total Air Handler Vent. Air (100.00% of Supply):	753 L/s

Total Conditioned Air Space:	82 Sq.m
Supply Air Per Unit Area:	9.1897 L/s/Sq.m
Area Per Cooling Capacity:	2.1249 Sq.m/kW
Cooling Capacity Per Area:	0.4706 kW/Sq.m



7.4731 Sq.m/Ton
 0.1338 Tons/Sq.m

Total Heating Required With Outside Air:	10.38 kW
Total Cooling With Outside Air:	38.54 kW

10.96 Tons

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 CIP N° 2154697

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #18 - N2 Unidad Precisión - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
172	2123 Centro De Datos 7pm December	39 1 116	2,778 230 5.96	22,834 2,350 61.04	63 0 0	2/Hr 64 64	2/Hr 64 64
Zone Peak Totals:		39	2,778	22,834	63		
Total Zones: 1		1	230	2,350	0	64	64
Unique Zones: 1		116	5.96	61.04	0	64	64




 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138





 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO


 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DNI N° 21546425



 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10



Air Handler #18 - N2 Unidad Precisión - Total Load Summary

Air Handler Description: N2 Unidad Precisión Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 1.00 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 6pm in January.
 Outdoor Conditions: 28° DB, 24° WB, 16.48 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in December at 7pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 22,834.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss: 2,778 Watts
 Infiltration sensible loss: 0 Watts 0 L/s
 Outside Air sensible loss: 311 Watts 64 L/s
 Supply Duct sensible loss: 0 Watts
 Return Duct sensible loss: 0 Watts
 Return Plenum sensible loss: 0 Watts
 Total System sensible loss: 3,089 Watts

Heating Supply Air: 2,778 / (1.000 X 1.21 X 10) = 230 L/s
 Winter Vent Outside Air (27.9% of supply) = 64 L/s

Zone space sensible gain: 22,834 Watts
 Infiltration sensible gain: 0 Watts
 Draw-thru fan sensible gain: 0 Watts
 Supply duct sensible gain: 289 Watts
 Reserve sensible gain: 0 Watts
 Total sensible gain on supply side of coil: 23,123 Watts

Cooling Supply Air: 23,123 / (1.000 X 1.23 X 8) = 2,350 L/s
 Summer Vent Outside Air (2.7% of supply) = 64 L/s

Return duct sensible gain: 289 Watts
 Return plenum sensible gain: 0 Watts
 Outside air sensible gain: 631 Watts 64 L/s
 Blow-thru fan sensible gain: 0 Watts
 Total sensible gain on return side of coil: 920 Watts
 Total sensible gain on air handling system: 24,043 Watts

Zone space latent gain: 63 Watts
 Infiltration latent gain: 0 Watts
 Outside air latent gain: 1,882 Watts
 Total latent gain on air handling system: 1,945 Watts
 Total system sensible and latent gain: 25,988 Watts

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN
 23,123 Watts

CONFORME

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Check Figures

Total Air Handler Supply Air (based on a 8° TD): 2,350 L/s
 Total Air Handler Vent. Air (2.73% of Supply): 64 L/s
 Total Conditioned Air Space: 39 Sq.m
 Supply Air Per Unit Area: 61.0364 L/s/Sq.m
 Area Per Cooling Capacity: 1.4815 Sq.m/kW 5.2101 Sq.m/Ton
 Cooling Capacity Per Area: 0.6750 kW/Sq.m 0.1919 Tons/Sq.m
 Total Heating Required With Outside Air: 3.09 kW
 Total Cooling With Outside Air: 25.99 kW 7.39 Tons

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29880

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #19 - Uma-n3-hosp - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
225	372 Sala Hosp Pediatria Pre Escolar 3pm January	25	2,028	3,541	168	2/Hr	2/Hr
		2	168	264	0	42	42
		75	6.73	10.61	0	46	44
226	374 Sala Hosp Pediatria Adolesc 3pm January	27	2,046	3,645	168	2/Hr	2/Hr
		2	169	272	0	45	45
		80	6.31	10.15	0	46	45
227	376 Sala Hosp Obstetricia 3pm January	25	2,028	3,541	168	2/Hr	2/Hr
		2	168	264	0	42	42
		75	6.73	10.61	0	46	44
228	378 Sala Hosp Obstetricia 3pm January	26	2,013	3,574	168	2/Hr	2/Hr
		2	166	267	0	43	43
		77	6.47	10.37	0	45	44
229	380 Sala De Monitoreo De Gestante 3pm January	37	2,131	4,359	168	2/Hr	2/Hr
		2	176	325	0	61	61
		110	4.81	8.88	0	48	54
Zone Peak Totals:		139	10,246	18,660	840		
Total Zones: 5		10	847	1,392	0	232	232
Unique Zones: 5		417	6.10	10.02	0	232	231

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

CONFORME

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29800

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 BNI N° 21948425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61779



Air Handler #19 - Uma-n3-hosp - Total Load Summary

Air Handler Description: Uma-n3-hosp Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 0.96 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in January.
 Outdoor Conditions: 30° DB, 24° WB, 16.39 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss: 10,246 Watts
 Infiltration sensible loss: 0 Watts 0 L/s
 Outside Air sensible loss: 1,120 Watts 232 L/s
 Supply Duct sensible loss: 0 Watts
 Return Duct sensible loss: 0 Watts
 Return Plenum sensible loss: 0 Watts
 Total System sensible loss: 11,367 Watts

Heating Supply Air: 10,246 / (1.000 X 1.21 X 10) = 847 L/s
 Winter Vent Outside Air (27.3% of supply) = 232 L/s

Zone space sensible gain: 18,660 Watts
 Infiltration sensible gain: 0 Watts
 Draw-thru fan sensible gain: 0 Watts
 Supply duct sensible gain: 171 Watts
 Reserve sensible gain: 0 Watts
 Total sensible gain on supply side of coil: 18,831 Watts

Cooling Supply Air: 18,831 / (1.000 X 1.23 X 11) = 1,392 L/s
 Summer Vent Outside Air (16.6% of supply) = 232 L/s

Return duct sensible gain: 171 Watts
 Return plenum sensible gain: 0 Watts
 Outside air sensible gain: 1,993 Watts 232 L/s
 Blow-thru fan sensible gain: 0 Watts
 Total sensible gain on return side of coil: 2,164 Watts
 Total sensible gain on air handling system: 20,995 Watts

Zone space latent gain: 840 Watts
 Infiltration latent gain: 0 Watts
 Outside air latent gain: 5,191 Watts
 Total latent gain on air handling system: 6,031 Watts
 Total system sensible and latent gain: 27,026 Watts

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION
 18,831 Watts

CONFORME
 2,164 Watts
 20,995 Watts

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69136

Check Figures

Total Air Handler Supply Air (based on a 11° TD): 1,392 L/s
 Total Air Handler Vent. Air (16.63% of Supply): 232 L/s
 Total Conditioned Air Space: 139 Sq.m
 Supply Air Per Unit Area: 10.0203 L/s/Sq.m
 Area Per Cooling Capacity: 5.1395 Sq.m/kW
 Cooling Capacity Per Area: 0.1946 kW/Sq.m 18.0748 Sq.m/Ton 0.0553 Tons/Sq.m
 Total Heating Required With Outside Air: 11.37 kW
 Total Cooling With Outside Air: 27.03 kW 7.68 Tons



[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 298

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61775



Air Handler #20 - Uma-n3-aisl.pediat - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
223	365 Esclusa 3pm April	5	745	828	84	None	None
		1	47	62	0	0	0
		16	9.10	11.87	0	47	62
224	366 Sala Hosp Pediatria Aislado 2pm May	15	1,249	2,839	84	None	None
		1	79	212	0	0	0
		46	5.16	13.75	0	79	212
Zone Peak Totals:		21	1,993	3,666	168		
Total Zones: 2		2	127	273	0	0	0
Unique Zones: 2		62	6.15	13.27	0	127	273

ARQ. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29800

CONSORCIO CONSULTOR SAUL GARRIDO

 C.P.C. MARIA LUISA CARBALLO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21946425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

004081



Air Handler #20 - Uma-n3-aisl.pediat - Total Load Summary

Air Handler Description: Uma-n3-aisl.pediat Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.20 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.96 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in May at 2pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 3,655.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	1,993 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	613 Watts	127 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

Heating Supply Air: $1,993 / (1.000 \times 1.21 \times 13) =$	127 L/s
Winter Vent Outside Air (100.0% of supply) =	127 L/s

Zone space sensible gain:	3,561 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	34 Watts
Reserve sensible gain:	0 Watts
Total sensible gain on supply side of coil:	

Cooling Supply Air: $3,688 / (1.000 \times 1.23 \times 11) =$	273 L/s
Summer Vent Outside Air (100.0% of supply) =	273 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	2,347 Watts	273 L/s
Blow-thru fan sensible gain:	204 Watts	
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

Zone space latent gain:	168 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	7,417 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

[Handwritten Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 6776
 I.E. 2007 SUPERVISOR

CONFORME
 3,594 Watts

[Handwritten Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REC. CIP. N° 69108
 2,551 Watts
 6,145 Watts
 7,585 Watts
 13,731 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	273 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	273 L/s	
Total Conditioned Air Space:	21 Sq.m	
Supply Air Per Unit Area:	13.2340 L/s/Sq.m	
Area Per Cooling Capacity:	1.5003 Sq.m/kW	5.2764 Sq.m/Ton
Cooling Capacity Per Area:	0.6665 kW/Sq.m	0.1895 Tons/Sq.m
Total Heating Required With Outside Air:	2.61 kW	
Total Cooling With Outside Air:	13.73 kW	3.90 Tons



[Handwritten Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP. 29500

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21346625

[Handwritten Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.E. N° 61770

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

10/10/10

004989



Air Handler #21 - Uma-n3-aisl.adulto - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
236	395 Esclusa 3pm April	8	1,080	1,123	67	None	None
		1	69	84	0	0	0
		24	8.58	10.47	0	69	84
238	3102 Sala Hosp Adultos Aislado 2pm May	20	1,592	3,507	84	None	None
		1	101	262	0	0	0
		61	5.01	12.95	0	101	262
Zone Peak Totals:		28	2,672	4,630	151		
Total Zones: 2		2	170	345	0	0	0
Unique Zones: 2		85	6.02	12.25	0	170	345

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



MANUEL DONATO GARCIA JAVE
 ING. MECANICO ELECTRICISTA
 REG. CIP N° 69138

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 298.3

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBALLO MUÑOZ
 REPRESENTANTE COMÚN
 DNI/N° 21946425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778



Air Handler #21 - Uma-n3-aisl.adulto - Total Load Summary

Air Handler Description: Uma-n3-aisl.adulto Constant Volume - Sum of Peaks
 Supply Air Fan: Blow-Thru with program estimated horsepower of 0.26 kW
 Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
 Sensible Heat Ratio: 0.97 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 2pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.46 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in May at 2pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 4,612.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	2,672 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	822 Watts	170 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

Heating Supply Air: 2,672 / (1.000 X 1.21 X 13) =	170 L/s
Winter Vent Outside Air (100.0% of supply) =	170 L/s

Zone space sensible gain:	4,497 Watts	
Infiltration sensible gain:	0 Watts	
Draw-thru fan sensible gain:	0 Watts	
Supply duct sensible gain:	42 Watts	
Reserve sensible gain:	12 Watts	
Total sensible gain on supply side of coil:		4,551 Watts

Cooling Supply Air: 4,666 / (1.000 X 1.23 X 11) =	345 L/s
Summer Vent Outside Air (100.0% of supply) =	345 L/s

Return duct sensible gain:	0 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	2,969 Watts	345 L/s
Blow-thru fan sensible gain:	258 Watts	
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		3,227 Watts

Zone space latent gain:	151 Watts	
Infiltration latent gain:	0 Watts	
Outside air latent gain:	9,384 Watts	
Total latent gain on air handling system:		9,535 Watts
Total system sensible and latent gain:		17,313 Watts

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	345 L/s	
Total Air Handler Vent. Air (100.00% of Supply):	345 L/s	
Total Conditioned Air Space:	28 Sq.m	
Supply Air Per Unit Area:	12.2300 L/s/Sq.m	
Area Per Cooling Capacity:	1.6288 Sq.m/kW	5.7283 Sq.m/Ton
Cooling Capacity Per Area:	0.6139 kW/Sq.m	0.1746 Tons/Sq.m
Total Heating Required With Outside Air:	3.49 kW	
Total Cooling With Outside Air:	17.31 kW	4.92 Tons



[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29803

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DNI N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770

004078



Air Handler #22 - Uma-n3-aisl.obst - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
239	3104 Sala Hosp Obstetricia Aisl 4pm January	20	1,598	3,926	168	None	None
		2	102	293	0	0	0
		61	4.98	14.35	0	102	293
240	3105 Esclusa 3pm April	8	1,047	1,254	67	None	None
		1	67	94	0	0	0
		24	8.32	11.69	0	67	94
Zone Peak Totals:		28	2,645	5,180	235		
Total Zones: 2		3	168	386	0	0	0
Unique Zones: 2		85	5.92	13.60	0	168	386

[Signature]
 ARQ. DAVID TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP. N° 00106

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29883

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DM N° 21546425

[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61779



Air Handler #22 - Uma-n3-aisl.obst - Total Load Summary

Air Handler Description: Uma-n3-aisl.obst Constant Volume - Sum of Peaks
Supply Air Fan: Blow-Thru with program estimated horsepower of 0.29 kW
Fan Input: 80% motor and fan efficiency with 0.6 kPa across the fan
Sensible Heat Ratio: 0.96 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in April.
Outdoor Conditions: 30° DB, 25° WB, 17.46 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in January at 4pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 5,139.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	2,645	Watts	
Infiltration sensible loss:	0	Watts	0 L/s
Outside Air sensible loss:	814	Watts	168 L/s
Supply Duct sensible loss:	0	Watts	
Return Duct sensible loss:	0	Watts	
Return Plenum sensible loss:	0	Watts	
Total System sensible loss:			

[Signature]
ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISION

Heating Supply Air: 2,645 / (1.000 X 1.21 X 13) =	168	L/s
Winter Vent Outside Air (100.0% of supply) =	168	L/s

Zone space sensible gain:	4,873	Watts
Infiltration sensible gain:	0	Watts
Draw-thru fan sensible gain:	0	Watts
Supply duct sensible gain:	47	Watts
Reserve sensible gain:	27	Watts
Total sensible gain on supply side of coil:		

4,948 Watts

Cooling Supply Air: 5,213 / (1.000 X 1.23 X 11) =	385	L/s
Summer Vent Outside Air (100.0% of supply) =	385	L/s

Return duct sensible gain:	0	Watts
Return plenum sensible gain:	0	Watts
Outside air sensible gain:	3,318	Watts
Blow-thru fan sensible gain:	288	Watts
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

3,606 Watts
8,554 Watts

Zone space latent gain:	235	Watts
Infiltration latent gain:	0	Watts
Outside air latent gain:	10,485	Watts
Total latent gain on air handling system:		
Total system sensible and latent gain:		

[Signature]
MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REC. CAP. N° 03108

10,720 Watts
19,274 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	385	L/s
Total Air Handler Vent. Air (100.00% of Supply):	385	L/s

Total Conditioned Air Space:	28	Sq.m
Supply Air Per Unit Area:	13.5694	L/s/Sq.m
Area Per Cooling Capacity:	1.4735	Sq.m/kW
Cooling Capacity Per Area:	0.6787	kW/Sq.m



5.1820 Sq.m/Ton
0.1930 Tons/Sq.m

Total Heating Required With Outside Air:	3.46	kW
Total Cooling With Outside Air:	19.27	kW

5.48 Tons

[Signature]
Nestor Enrique Ruiz R.
Ingeniero Mecánico
Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

[Signature]
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

[Signature]
EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N° 61770



Air Handler #24 - Uma-n2-recup - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
126	237 Sala De Recuperación Post Anestésica 3pm April	103	4,358	9,716	284	2/Hr	2/Hr
		6	360	725	0	172	172
		309	3.50	7.04	0	172	171
Zone Peak Totals:		103	4,358	9,716	284		
Total Zones: 1		6	360	725	0	172	172
Unique Zones: 1		309	3.50	7.04	0	172	171

ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

CONFORME



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 03108

Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61777

878100

1948

1948-1949

1949

1949-1950

1950-1951

1951-1952

1952-1953



Air Handler #24 - Uma-n2-recup - Total Load Summary

Air Handler Description: Uma-n2-recup Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 0.97 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	4,358 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	830 Watts	172 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

[Handwritten Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP 6178
 JEFE DE SUPERVISION

Heating Supply Air: $4,358 / (1.000 \times 1.21 \times 10) =$ 360 L/s
 Winter Vent Outside Air (47.6% of supply) = 172 L/s

Zone space sensible gain:	9,716 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	89 Watts
Reserve sensible gain:	0 Watts
Total sensible gain on supply side of coil:	

9,805 Watts

Cooling Supply Air: $9,805 / (1.000 \times 1.23 \times 11) =$ 725 L/s
 Summer Vent Outside Air (23.7% of supply) = 172 L/s

Return duct sensible gain:	89 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	1,477 Watts	172 L/s
Blow-thru fan sensible gain:	0 Watts	
Total sensible gain on return side of coil:		
Total sensible gain on air handling system:		

CONFORME

1,566 Watts
 11,371 Watts

Zone space latent gain:	284 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	4,666 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

[Handwritten Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 02100

4,950 Watts
 16,321 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	725 L/s	
Total Air Handler Vent. Air (23.66% of Supply):	172 L/s	
Total Conditioned Air Space:	103 Sq.m	
Supply Air Per Unit Area:	7.0433 L/s/Sq.m	
Area Per Cooling Capacity:	6.3048 Sq.m/kW	22.1732 Sq.m/Ton
Cooling Capacity Per Area:	0.1586 kW/Sq.m	0.0451 Tons/Sq.m
Total Heating Required With Outside Air:	5.19 kW	
Total Cooling With Outside Air:	16.32 kW	4.64 Tons



[Handwritten Signature]
 Nestor Enrique Ruiz F.,
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
[Handwritten Signature]
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DMI N° 21546425

[Handwritten Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61778

004974



Air Handler #25 - Uma-n3-hosp.adult - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
200	316 Sala Hosp Adultos Varones 2pm May	23 3 68	1,649 136 5.98	3,845 287 12.58	252 0 0	2/Hr 38 36	2/Hr 38 41
205	331 Sala Hospit Adulto Mujeres 2pm April	25 2 74	1,858 154 6.19	3,374 252 10.15	168 0 0	2/Hr 41 41	2/Hr 41 36
206	333 Sala Hospit Adulto Mujeres 2pm April	25 2 74	1,858 154 6.19	3,374 252 10.15	168 0 0	2/Hr 41 41	2/Hr 41 36
207	334 Sala Hospit Adulto Mujeres 2pm April	25 2 74	1,858 154 6.19	3,374 252 10.15	168 0 0	2/Hr 41 41	2/Hr 41 36
232	387 Sala Hosp Adultos Varones 2pm May	20 2 60	1,591 132 6.54	3,586 267 13.31	169 0 0	2/Hr 34 35	2/Hr 34 38
233	388 Sala Hosp Adultos Varones 2pm May	20 2 60	1,591 132 6.54	3,586 267 13.31	169 0 0	2/Hr 34 35	2/Hr 34 38
235	393 Sala Hosp Adultos Varones 2pm May	20 2 60	1,591 132 6.54	3,586 267 13.31	169 0 0	2/Hr 34 35	2/Hr 34 38
Zone Peak Totals:		158	11,997	24,726	1,263		
Total Zones: 7		15	992	1,844	0	263	263
Unique Zones: 7		472	6.30	11.71	0	263	263



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 92130

CONFORME

Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29866

CONSORCIO CONSULTOR SAUL GARRIDO
Maria Luisa Carabajo Muñoz
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

Edward Cerón Torres
 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770

David Hektor Torres Puente
 ARQ. DAVID HEKTOR TORRES PUENTE
 CAP. 6776



Air Handler #25 - Uma-n3-hosp.adult - Total Load Summary

Air Handler Description: Uma-n3-hosp.adult Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 0.95 --- This system occurs 1 time(s) in the building. ---
 Air System Peak Time: 2pm in April.
 Outdoor Conditions: 30° DB, 25° WB, 17.46 grains

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in May at 2pm is different from the total system peak time, hence the air system L/s was computed using a zone sensible load of 24,476.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	11,997 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	1,271 Watts	263 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		

(Signature)
 ARQ DAVID TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN
 13,268 Watts

Heating Supply Air: 11,997 / (1.000 X 1.21 X 10) =	992 L/s
Winter Vent Outside Air (26.5% of supply) =	263 L/s

Zone space sensible gain:	24,199 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	227 Watts
Reserve sensible gain:	242 Watts
Total sensible gain on supply side of coil:	

24,667 Watts

Cooling Supply Air: 24,944 / (1.000 X 1.23 X 11) =	1,844 L/s
Summer Vent Outside Air (14.2% of supply) =	263 L/s

Return duct sensible gain:	227 Watts
Return plenum sensible gain:	0 Watts
Outside air sensible gain:	2,260 Watts
Blow-thru fan sensible gain:	0 Watts
Total sensible gain on return side of coil:	
Total sensible gain on air handling system:	

(Signature)

2,487 Watts
 27,154 Watts

Zone space latent gain:	1,263 Watts
Infiltration latent gain:	0 Watts
Outside air latent gain:	7,142 Watts
Total latent gain on air handling system:	
Total system sensible and latent gain:	

(Signature)
 MANUEL DOMINGO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 61013

8,405 Watts
 35,559 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	1,844 L/s	
Total Air Handler Vent. Air (14.24% of Supply):	263 L/s	
Total Conditioned Air Space:	158 Sq.m	
Supply Air Per Unit Area:	11.7056 L/s/Sq.m	
Area Per Cooling Capacity:	4.4293 Sq.m/kW	15.5772 Sq.m/Ton
Cooling Capacity Per Area:	0.2258 kW/Sq.m	0.0642 Tons/Sq.m
Total Heating Required With Outside Air:	13.27 kW	
Total Cooling With Outside Air:	35.56 kW	10.11 Tons



(Signature)
 Nestor Enrique Ruiz R.
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
(Signature)
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

(Signature)
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770

004872



Air Handler #26 - Uma-n3-hosp.obst - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
237	399 Sala De Ginecologia 4pm January	19 2 57	1,558 129 6.78	3,831 286 15.04	168 0 0	2/Hr 32 32	2/Hr 32 33
241	3108 Sala Hosp Ginecologia 4pm January	19 2 57	1,558 129 6.78	3,831 286 15.04	168 0 0	2/Hr 32 32	2/Hr 32 33
242	3109 Sala Hosp Cesareas 4pm January	20 2 61	1,592 132 6.51	3,911 292 14.44	168 0 0	2/Hr 34 33	2/Hr 34 33
243	3112 Sala Hosp Cesareas 4pm January	20 2 61	1,592 132 6.51	3,911 292 14.44	168 0 0	2/Hr 34 33	2/Hr 34 33
244	3115 Sala Hosp Cesareas 4pm January	20 2 61	1,592 132 6.51	3,911 292 14.44	168 0 0	2/Hr 34 33	2/Hr 34 33
245	3116 Sala Hosp Cesareas 4pm January	20 2 61	1,592 132 6.51	3,911 292 14.44	168 0 0	2/Hr 34 33	2/Hr 34 33
246	3120 Sala Hosp Obstetricia 4pm January	20 2 61	1,647 136 6.74	3,948 294 14.58	168 0 0	2/Hr 34 34	2/Hr 34 34
Zone Peak Totals:		139	11,132	27,255	1,176		
Total Zones: 7		14	920	2,033	0	232	232
Unique Zones: 7		417	6.62	14.63	0	232	232



MANUEL DONATO GARCIA IAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 53130

Nestor Enrique Ruiz P.
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

Edward Cerón Torres
 JEFE DE PROYECTO
 C.I.P. N° 61778

CONFORME

David Piedra



Air Handler #26 - Uma-n3-hosp.obst - Total Load Summary

Air Handler Description: Uma-n3-hosp.obst Constant Volume - Sum of Peaks
 Sensible Heat Ratio: 0.96 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in January.
 Outdoor Conditions: 30° DB, 24° WB, 16.50 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	11,132 Watts	
Infiltration sensible loss:	0 Watts	0 L/s
Outside Air sensible loss:	1,121 Watts	232 L/s
Supply Duct sensible loss:	0 Watts	
Return Duct sensible loss:	0 Watts	
Return Plenum sensible loss:	0 Watts	
Total System sensible loss:		12,253 Watts

Heating Supply Air: $11,132 / (1.000 \times 1.21 \times 10) =$	920 L/s
Winter Vent Outside Air (25.2% of supply) =	232 L/s

Zone space sensible gain:	27,255 Watts
Infiltration sensible gain:	0 Watts
Draw-thru fan sensible gain:	0 Watts
Supply duct sensible gain:	250 Watts
Reserve sensible gain:	0 Watts
Total sensible gain on supply side of coil:	



 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISION
 27,505 Watts

Cooling Supply Air: $27,505 / (1.000 \times 1.23 \times 11) =$	2,033 L/s
Summer Vent Outside Air (11.4% of supply) =	232 L/s

Return duct sensible gain:	250 Watts	
Return plenum sensible gain:	0 Watts	
Outside air sensible gain:	1,995 Watts	232 L/s
Blow-thru fan sensible gain:	0 Watts	
Total sensible gain on return side of coil:		2,245 Watts
Total sensible gain on air handling system:		29,750 Watts



 MANUEL DONATO GARCIA JAIME
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

Zone space latent gain:	1,176 Watts	
Infiltration latent gain:	0 Watts	
Outside air latent gain:	5,195 Watts	
Total latent gain on air handling system:		6,371 Watts
Total system sensible and latent gain:		36,121 Watts

Check Figures

Total Air Handler Supply Air (based on a 11° TD):	2,033 L/s	
Total Air Handler Vent. Air (11.40% of Supply):	232 L/s	
Total Conditioned Air Space:	139 Sq.m	
Supply Air Per Unit Area:	14.6254 L/s/Sq.m	
Area Per Cooling Capacity:	3.8482 Sq.m/kW	13.5336 Sq.m/Ton
Cooling Capacity Per Area:	0.2599 kW/Sq.m	0.0739 Tons/Sq.m
Total Heating Required With Outside Air:	12.25 kW	
Total Cooling With Outside Air:	36.12 kW	10.27 Tons

CONFORME






 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO


 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425



 EDWARD CERÓN TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770

004970



Air Handler #27 - Uma-n3-hosp.ped - Summary Loads

Zn No	Description Peak Time	Area People Volume	Htg.Loss Htg.L/s L/s/Sqm	Sen.Gain Clg.L/s L/s/Sqm	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.L/s Act.L/s	Clg.O.A. Req.L/s Act.L/s
212	345 Sala Hosptt Pediatria Escolar 2pm April	25 2 74	1,845 152 6.20	3,352 250 10.16	168 0 0	2/Hr 41 39	2/Hr 41 33
213	347 Sala Hosptt Pediatria Escolar 2pm April	25 2 74	1,845 152 6.20	3,352 250 10.16	168 0 0	2/Hr 41 39	2/Hr 41 33
217	353 Atención Al Recien Nacido Sano 3pm January	13 2 39	1,120 93 7.12	2,479 185 14.22	94 0 0	2/Hr 22 24	2/Hr 22 25
218	354 Atención Recién Nacido Patologico 3pm January	16 3 49	1,333 110 6.76	2,954 220 13.52	142 0 0	2/Hr 27 28	2/Hr 27 29
221	359 Sala Hosp Pediatria Lactante 2pm May	13 3 40	1,172 97 7.34	2,840 212 16.05	252 0 0	2/Hr 22 25	2/Hr 22 28
222	361 Sala Hosp Pediatria Adolesc 2pm May	15 3 46	1,193 99 6.40	2,962 221 14.35	252 0 0	2/Hr 26 25	2/Hr 26 29
Zone Peak Totals:		107	8,509	17,938	1,076		
Total Zones: 6		15	703	1,338	0	179	179
Unique Zones: 6		321	6.57	12.49	0	179	179



Nestor Enrique Ruiz
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863



MANUEL DONATO GARCIA JAVE
 ING. MECANICO-EL. ELECTRICISTA
 REG. CIP N° 69103

CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA LOISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 ARQ. DAVID TORRES PUEENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN



[Signature]
 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770

001009



Air Handler #27 - Uma-n3-hosp.ped - Total Load Summary

Air Handler Description: Uma-n3-hosp.ped Constant Volume - Sum of Peaks
Sensible Heat Ratio: 0.94 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in April.
Outdoor Conditions: 30° DB, 25° WB, 17.34 grains

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Zone Space sensible loss:	8,509	Watts	
Infiltration sensible loss:	0	Watts	0 L/s
Outside Air sensible loss:	864	Watts	179 L/s
Supply Duct sensible loss:	0	Watts	
Return Duct sensible loss:	0	Watts	
Return Plenum sensible loss:	0	Watts	
Total System sensible loss:			


 ARQ. DAVID HECTOR TORRES PUENTES
 CAP. 5776
 JEFE DE SUPERVISIÓN

Heating Supply Air: $8,509 / (1.000 \times 1.21 \times 10) =$ 703 L/s
 Winter Vent Outside Air (25.4% of supply) = 179 L/s

Zone space sensible gain:	16,979	Watts	
Infiltration sensible gain:	0	Watts	
Draw-thru fan sensible gain:	0	Watts	
Supply duct sensible gain:	164	Watts	
Reserve sensible gain:	947	Watts	
Total sensible gain on supply side of coil:			

18,091 Watts

Cooling Supply Air: $18,091 / (1.000 \times 1.23 \times 11) =$ 1,337 L/s
 Summer Vent Outside Air (13.3% of supply) = 179 L/s

CONFORME

Return duct sensible gain:	164	Watts	
Return plenum sensible gain:	0	Watts	
Outside air sensible gain:	1,537	Watts	179 L/s
Blow-thru fan sensible gain:	0	Watts	
Total sensible gain on return side of coil:			
Total sensible gain on air handling system:			

1,701 Watts
19,792 Watts

Zone space latent gain:	1,076	Watts	
Infiltration latent gain:	0	Watts	
Outside air latent gain:	4,857	Watts	
Total latent gain on air handling system:			
Total system sensible and latent gain:			


 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 63153

5,933 Watts
25,725 Watts


Check Figures

Total Air Handler Supply Air (based on a 11° TD):	1,337	L/s	
Total Air Handler Vent. Air (13.35% of Supply):	179	L/s	
Total Conditioned Air Space:	107	Sq.m	
Supply Air Per Unit Area:	12.4848	L/s/Sq.m	
Area Per Cooling Capacity:	4.1633	Sq.m/kW	14.6417 Sq.m/Ton
Cooling Capacity Per Area:	0.2402	kW/Sq.m	0.0683 Tons/Sq.m
Total Heating Required With Outside Air:	9.37	kW	
Total Cooling With Outside Air:	25.72	kW	7.31 Tons




 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425


 EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 61770



Zone Detailed Loads (At Zone Peak Times)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
------------------	-----------	-----------	-----------	-------------	-----------	-----------	------------	-----------

Zone 1-101 Entrevista Familiar peaks (sensible) in May at 8am, Air Handler 1 (Fc), Group 0, 1.0 x 9.2, Construction Type: 1 (Light)

Wall-2-ENE-B-M	8	0.83	5.0	2.000	77		6.000	47
Wall-3-NNW-B-M	14	0.83	7.8	2.000	211		6.000	82
Partition-1-1	18.4		4/8	2.360	174		18.880	347
Partition-4-2	45.6		4/8	2.210	403		17.680	806
Gls-ENE-1-90-Tran	1.8	1.000	-2	5.700	-17		17.400	31
0%S-0-WS-Solar	1.8	0.700	638	0.790	635			
Lights-Prof=1	92	1.000			92			
Equipment-Prof=1	200	1.000			200	0		
People-Prof=1	6.0	1.000			450	360		

Sub-total					2,225	360		
Safety factors:					+5%	+5%		
Total w/ safety factors:					2,336	378		1,418

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776 +8%
 JEFE DE SUPERVISION

Zone 2-105 Estar Choferes peaks (sensible) in April at 9am, Air Handler 1 (Fc), Group 0, 1.0 x 12.0, Construction Type: 1 (Light)

Wall-2-ENE-B-M	9	0.83	5.6	2.000	104		6.000	56
Partition-1-2	12		4/8	2.210	106		17.680	212
Partition-3-2	45.6		4/8	2.210	403		17.680	806
Gls-ENE-1-90-Tran	1.8	1.000	0	5.700	-1		17.400	31
0%S-0-WS-Solar	1.8	0.700	647	0.798	651			
Lights-Prof=1	120	1.000			120			
Equipment-Prof=1	200	1.000			200	0		
People-Prof=1	5.0	1.000			350	225		

Sub-total					1,933	225		1,106
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,030	236		1,195

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRUISTA
 REG. CIP N° 33133

CONFORME

Zone 3-107 Triaje peaks (sensible) in December at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 10.7, Construction Type: 1 (Light)

Partition-1-2	10.7		4/8	2.210	95		17.680	189
Partition-2-2	52.4		4/8	2.210	463		17.680	926
Lights-Prof=1	107	1.000			107			
Equipment-Prof=1	300	1.000			300	0		
People-Prof=1	3.0	1.000			240	240		

Sub-total					1,205	240		1,115
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					1,265	252		1,205



CONSORCIO CONSULTOR SAUL GARRIDO

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DMI N° 21546425

Zone 4-108 Espera peaks (sensible) in May at 2pm, Air Handler 1 (Fc), Group 0, 1.0 x 109.1, Construction Type: 1 (Light)

Wall-2-NNW-B-M	34	0.83	6.1	2.000	416		6.000	205
Partition-1-2	109.1		4/8	2.210	964		17.680	1,929
Partition-3-2	153.2		4/8	2.210	1,354		17.680	2,709

[Signature]

• ybba 0

944

1944
1945
1946

1947
1948
1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Gls-NNW-1-90-Tran	7.4	1.000	5	5.700	225		17.400	129
0%S-0-WS-Solar	7.4	0.700	481	0.833	2,087			
Lights-Prof=1	1,091	1.000			1,091			
Equipment-Prof=1	450	1.000			450	0		
People-Prof=1	19.0	1.000			1,330	855		
Sub-total					7,918	855		
Safety factors:					+5%	+5%		
Total w/ safety factors:					8,314	898		5,370

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 67764,972
 JEFE DE SUPERVISION

Zone 5-109 Servicio Social peaks (sensible) in May at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 9.5, Construction Type: 1 (Light)

Wall-2-NNW-B-M	14	0.83	10.2	2.000	287		6.000	84
Partition-1-2	9.5		4/8	2.210	84		17.680	168
Partition-3-1	35.6		4/8	2.360	336		18.880	672
Lights-Prof=1	95	1.000			95			
Equipment-Prof=1	300	1.000			300	0		
People-Prof=1	3.0	1.000			225	180		
Sub-total					1,327	180		924
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					1,393	189		998

Zone 6-110 Ref Cref peaks (sensible) in December at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 9.4, Construction Type: 1 (Light)

Partition-1-2	9.4		4/8	2.210	83		17.680	166
Partition-2-2	49.2		4/8	2.210	435		17.680	870
Lights-Prof=1	94	1.000			94			
Equipment-Prof=1	300	1.000			300	0		
People-Prof=1	3.0	1.000			225	180		
Sub-total					1,137	180		1,036
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					1,194	189		1,119

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 69138

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

Zone 7-111 Seguros peaks (sensible) in December at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 10.4, Construction Type: 1 (Light)

Partition-1-2	10.4		4/8	2.210	92		17.680	184
Partition-2-1	51.6		4/8	2.360	487		18.880	974
Lights-Prof=1	104	1.000			104			
Equipment-Prof=1	300	1.000			300	0		
People-Prof=1	3.0	1.000			225	180		
Sub-total					1,208	180		1,158
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					1,268	189		1,251



CONSORCIO CONSULTOR SAUL GARRIDO

C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMUN
 DNI N° 21546425

CONFORME

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 69138

004966



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Zone 8-113 Admisión peaks (sensible) in December at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 12.7, Construction Type: 1 (Light)

Partition-1-2	12.7		4/8	2.210	112		17.680	225
Partition-2-2	57.6		4/8	2.210	509		17.680	1,018
Lights-Prof=1	127	1.000			127			
Equipment-Prof=1	600	1.000			600	0		
People-Prof=1	2.0	1.000			150	120		
Sub-total					1,498	120		
Safety factors:					+5%	+5%		
Total w/ safety factors:					1,573	126		1,342

[Signature]
 ARQ. DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISOR

Zone 9-113.1 Dispensación Y Expendio De Medicam peaks (sensible) in December at 7am, Air Handler 1 (Fc), Group 0, 1.0 x 30.9, Construction Type: 1 (Light)

Wall-2-SSE-B-M	19	0.83	6.2	2.000	242		6.000	116
Partition-1-1	30.9		4/8	2.360	292		18.880	583
Partition-3-2	48.8		4/8	2.210	431		17.680	863
Gls-SSE-1-90-Tran	5.0	1.000	-4	5.700	-117		17.400	88
0%S-0-WS-Solar	5.0	0.700	532	0.765	1,436			
Lights-Prof=1	309	1.000			309			
Equipment-Prof=1	600	1.000			600	0		
People-Prof=1	3.0	1.000			240	240		
Sub-total					3,433	240		1,650
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					3,604	252		1,782

[Signature]
 MANUEL DONATO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 93163

Zone 10-114 Topico De Intectables peaks (sensible) in January at 5pm, Air Handler 1 (Fc), Group 0, 1.0 x 21.8, Construction Type: 1 (Light)

Wall-2-WSW-B-M	9	0.83	6.0	2.000	113		6.000	57
Partition-1-2	21.8		4/8	2.210	193		17.680	385
Partition-3-2	63.2		4/8	2.210	559		17.680	1,117
Gls-WSW-1-90-Tran	2.5	1.000	6	5.700	79		17.400	44
0%S-0-WS-Solar	2.5	0.700	690	0.839	1,021			
Lights-Prof=1	218	1.000			218			
Equipment-Prof=1	450	1.000			450	0		
People-Prof=1	3.0	1.000			240	240		
Sub-total					2,873	240		1,604
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					3,016	252		1,732



CONSORCIO CONSULTOR SAUL GARRIDO
[Signature]
 C.P.C. MARIA JUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

[Signature]
 Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

Zone 11-115 Topico Cirugia peaks (sensible) in January at 5pm, Air Handler 1 (Fc), Group 0, 1.0 x 17.3, Construction Type: 1 (Light)

Wall-2-WSW-B-M	6	0.83	6.0	2.000	74		6.000	37
Partition-1-2	17.3		4/8	2.210	153		17.680	306
Partition-3-2	58.4		4/8	2.210	516		17.680	1,033
Gls-WSW-1-90-Tran	1.8	1.000	6	5.700	57		17.400	31
0%S-0-WS-Solar	1.8	0.700	690	0.839	729			
Lights-Prof=1	173	1.000			173			
Equipment-Prof=1	450	1.000			450	0		

CONFORME

[Signature]
 JEFE DE PROYECTO
 C.I.P. N° 61770



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Load Description	Unit Quan	-SC-CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
People-Prof=1	3.0	1.000			240	240		
Sub-total					2,392	240		1,407
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,512	252		1,519

Zone 12-116 Sala De Rehidratación peaks (sensible) in April at 9am, Air Handler 1 (Fc), Group 0, 1.0 x 15.3, Construction Type: 1 (Light)

Wall-2-ENE-B-M	11	0.83	5.6	2.000	123		6.000	67
Partition-1-2	15.3		4/8	2.210	135		17.680	271
Partition-3-2	48.8		4/8	2.210	431		17.680	863
Gls-ENE-1-90-Tran	2.9	1.000	0	5.700	-1		17.400	50
0%S-0-WS-Solar	2.9	0.700	647	0.798	1,041			
Lights-Prof=1	153	1.000			153			
Equipment-Prof=1	300	1.000			300			
People-Prof=1	3.0	1.000			240			
Sub-total					2,423	240		1,250
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,544	252		1,350

0
 240 RQ DAVID HECTOR TORRES PUENTE
 CAP. 5776
 JEFE DE SUPERVISIÓN

Zone 13-117 Topico Medicina peaks (sensible) in April at 9am, Air Handler 1 (Fc), Group 0, 1.0 x 16.1, Construction Type: 1 (Light)

Wall-2-ENE-B-M	12	0.83	5.6	2.000	132		6.000	72
Partition-1-2	16.1		4/8	2.210	142		17.680	285
Partition-3-2	49.6		4/8	2.210	438		17.680	877
Gls-ENE-1-90-Tran	2.9	1.000	0	5.700	-1		17.400	50
0%S-0-WS-Solar	2.9	0.700	647	0.798	1,041			
Lights-Prof=1	161	1.000			161			
Equipment-Prof=1	450	1.000			450			
People-Prof=1	3.0	1.000			240			
Sub-total					2,604	240		1,283
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,734	252		1,386

MANUEL IGNACIO GARCIA JAVE
 ING. MECANICO-ELECTRICISTA
 REG. CIP N° 59138

Nestor Enrique Ruiz
 Ingeniero Mecánico
 Reg. CIP 29863

Zone 14-118 Sala De Espera Para Reevaluación peaks (sensible) in April at 9am, Air Handler 1 (Fc), Group 0, 1.0 x 62.1, Construction Type: 1 (Light)

Wall-2-ENE-B-M	18	0.83	5.6	2.000	202		6.000	109
Partition-1-2	62.1		4/8	2.210	549		17.680	1,098
Partition-3-2	154		4/8	2.210	1,361		17.680	2,723
Gls-ENE-1-90-Tran	1.4	1.000	0	5.700	-1		17.400	25
0%S-0-WS-Solar	1.4	0.700	647	0.798	521			
Lights-Prof=1	621	1.000			621			
Equipment-Prof=1	300	1.000			300			
People-Prof=1	9.0	1.000			630			
Sub-total					4,183	405		3,955



CONSORCIO CONSULTOR SAUL GARRIDO
 C.P.C. MARIA LUISA CARBAJO MUÑOZ
 REPRESENTANTE COMÚN
 DNI N° 21546425

CONFORME

EDWARD CERON TORRES
 JEFE DE PROYECTO
 C.I.P. N° 6177°



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Load Description	Unit Quan	-SC-CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,861	142		1,265

Zone 22-132 Cuarto Técnico peaks (sensible) in January at 7pm, Air Handler 10 (Dx), Group 0, 1.0 x 9.4, Construction Type: 1 (Light)

Wall-2-WSW-B-M	8	0.83	10.6	2.000	179		6.000	50
Partition-1-1	9.4		4/8	2.360	89		18.880	177
Partition-3-1	44		4/8	2.360	415		18.880	831
Lights-Prof=1	94	1.000			94			
Equipment-Prof=1	1,500	1.000			1,500	0		
People-Prof=1	0.9	1.000			75	75		
Sub-total					2,352	75		
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,470	79		1,143

ARQ. DAVID HECTOR TORRES PUENTE
CAP. 5776
JEFE DE SUPERVISION

Zone 23-134 Estar De Personal De Guardia peaks (sensible) in January at 5pm, Air Handler 1 (Fc), Group 0, 1.0 x 15.3, Construction Type: 1 (Light)

Wall-2-WSW-B-M	10	0.83	6.0	2.000	118		6.000	59
Partition-1-2	15.3		4/8	2.210	135		17.680	271
Partition-3-1	51.2		4/8	2.360	483		18.880	967
Gls-WSW-1-90-Tran	2.2	1.000	6	5.700	68		17.400	38
0%S-0-WS-Solar	2.2	0.700	690	0.839	875			
Lights-Prof=1	153	1.000			153			
Equipment-Prof=1	200	1.000			200	0		
People-Prof=1	6.0	1.000			420	270		
Sub-total					2,452	270		
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					2,575	284		1,440

Nestor Enrique Ruiz
Ingeniero Mecánico
Reg. CIP 29866

MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REG. CIP N° 63103

Zone 24-142 Secretaria peaks (sensible) in December at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 10.7, Construction Type: 1 (Light)

Partition-1-2	10.7		4/8	2.210	95		17.680	189
Partition-2-1	54.8		4/8	2.360	517		18.880	1,035
Lights-Prof=1	107	1.000			107			
Equipment-Prof=1	300	1.000			300	0		
People-Prof=1	3.0	1.000			225	180		
Sub-total					1,244	180		1,224
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					1,306	189		1,322



CONSORCIO CONSULTOR SAUL GARRIDO
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
DNI N° 21546425

CONFORME

Zone 25-143 Jefatura peaks (sensible) in December at 7pm, Air Handler 1 (Fc), Group 0, 1.0 x 12.7, Construction Type: 1 (Light)

Partition-1-2	12.7		4/8	2.210	112		17.680	225
---------------	------	--	-----	-------	-----	--	--------	-----

EDWARD CERON TORRES
JEFE DE PROYECTO
C.I.P. N°



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Partition-2-1	58.4		4/8	2.360	551		18.880	1,103
Lights-Prof=1	127	1.000			127			
Equipment-Prof=1	300	1.000			300	0		
People-Prof=1	3.0	1.000			225	180		
Sub-total					1,316	180		1,327
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					1,381	189		1,433

[Handwritten Signature]
ARQ. DAVID HECTOR TORRES PUENTE
CAP. 6776
JEFE DE SUPERVISION

Zone 26-144 Sala De Observacion Mujeres peaks (sensible) in April at 9am, Air Handler 2 (Uma-n1-obs), Group 0, 1.0 x 150.6, Construction Type: 1 (Light)

Wall-2-ENE-B-M	28	0.83	5.6	2.000	312		8.000	225
Partition-1-2	150.6		4/8	2.210	1,331		17.680	2,663
Partition-3-2	225.6		4/8	2.210	1,994		17.680	3,989
Gls-ENE-1-90-Tran	5.9	1.000	0	5.700	-3		23.200	136
0%S-0-WS-Solar	5.9	0.700	647	0.798	2,126			
Lights-Prof=1	1,506	1.000			1,506			
Equipment-Prof=1	1,500	1.000			1,500	0		
People-Prof=1	8.0	1.000			640	640		
Sub-total					9,407	640		7,013
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					9,877	672		7,574

[Handwritten Signature]
MANUEL DONATO GARCIA JAVE
ING. MECANICO-ELECTRICISTA
REC. CIP N° 63133

Zone 27-147 Sala De Observacion Hombres peaks (sensible) in December at 7pm, Air Handler 2 (Uma-n1-obs), Group 0, 1.0 x 75.7, Construction Type: 1 (Light)

Partition-1-2	75.7		4/8	2.210	669		17.680	1,338
Partition-2-1	151.2		4/8	2.360	1,427		18.880	2,855
Lights-Prof=1	757	1.000			757			
Equipment-Prof=1	1,500	1.000			1,500	0		
People-Prof=1	5.0	1.000			400	400		
Sub-total					4,754	400		4,933
Safety factors:					+5%	+5%		+8%
Total w/ safety factors:					4,991	420		4,528

[Handwritten Signature]
Nestor Enrique Ruiz, Ing.
Ingeniero Mecánico
Reg. CIP 29866

Zone 28-148 Sala De Observación Pediatría peaks (sensible) in April at 9am, Air Handler 2 (Uma-n1-obs), Group 0, 1.0 x 42.6, Construction Type: 1 (Light)

Wall-2-ENE-B-M	20	0.83	5.6	2.000	224		8.000	161
Partition-1-2	42.6		4/8	2.210	377		17.680	753
Partition-3-2	83.6		4/8	2.210	739		17.680	1,478
Gls-ENE-1-90-Tran	5.0	1.000	0	5.700	-3		23.200	117
0%S-0-WS-Solar	5.0	0.700	647	0.798	1,822			
Lights-Prof=1	426	1.000			426			
Equipment-Prof=1	900	1.000			900	0		
People-Prof=1	3.0	1.000			240	240		
Sub-total					4,725	240		2,509



[Handwritten Signature]
C.P.C. MARIA LUISA CARBAJO MUÑOZ
REPRESENTANTE COMÚN
ONI N° 21546425

CONFORME